

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1		1		1				
3	MDK	107	933	2	1	2	1	2	1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	2	4	2	4	2	0	0	
	Grand Total	1082	6468	4	3	4	3	4	3	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.02.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koukuntla	33KV	Narayanpet	22.10	23.25	01.15	EL	AB Switch open at Gopan pally	Koukuntla	No
1	NLG	Marriguda	Shivannagudam	33KV	Devarakonda	14:52	16:20	1:28	EL	Tree Fallen on the Line	Shivannagudam	No
1	MDK	Kandi	HFC-II	33KV	Sangareddy	13:20	15:00	1:40		B/D Due to Conductor Snapped	HFC-II	No
2		Gummadidala	Bonthapally	33KV	Patancheru	12.30	14.25	01.55		B/D Due to Jumper Cut	Bonthapally	No

TSSPDCL - LMRC / Corporate office

Date: 03.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	Patancheru Town	High power	11KV	Patancheru	11:10	12:05	0:55		B/D Due to Conductor Snapped	No
1	SDPT	Nangnoor	Siddannapet	11KV	Siddipet	12:50	13:30	0:40		11KV Wire cut	No
1	HYD N	Janapriya	Bharath Nagar	11KV	IV	21.20	00.05	02.45	EL	Cable fault at Bharath Nagar Nala	22:15 Partial feeder charged & remaining loads added on 11KV Bharath Nagar fdr from IDPL SS