

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT			1	1	1	1	1	1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>2</b>	<b>5</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 05.02.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kothapally	33KV	Narayanpet	23.40	01.30	01.50	E/L	No Visible Fault		-
1	SDPT	HUSNABAD	THOTAPALLY	33KV	Husnabad	04.35	05.30	01.00		Under Breakdown		Alternative supply is using from katkoor feeder at 05.30 hrs

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 05.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Doopahad	New Banjarahills thanda	11KV	Suryapet	07.00	08.45	01.45	E/L	11Kv Insulator failed	-
1	SDPT	Jagdevpur SS	Dowlapur Feeder LC.No.5701	11KV	Gajwel	13.47	15.03	01.16		Near DTR jumeper Cut	-
1	RR N	Devarayamjal	DMC	11KV	Medchal	07.25	07.45	00.20	BD	No fault	-
2		Shameerpet	Devarayamjal	11KV	Medchal	07.30	08.20	00.50	BD	Bird fallen on the 11KV Line at HBL Colony Beside, Thumkunta	-
1	HYD C	Industrial Area	R.O.M	11KV	Azamabad	03.40	07.17	03.37	EL,OL-Y&Bph	Cable fault at Garunda Apts	Arranged B/F on 11KV Preventive Medicine fdr