

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT			1	1	1	1		1	1		1 No.33KV Still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	3	2	3	1	3	1	0	
	Grand Total	1082	6468	2	6	2	6	1	6	1	0	

TSSPDCL - LMRC / Corporate office

Date: 07.02.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Achampet	Kondanagula	33KV	Nagarkurnool	13.40	13.50	00.10		Y Phase LA Blast	Kondanagula	Alternate Supply Taken to 33KV Lingal Feeder at 13:50Hrs
1	SDPT	Thukkapur	Lingapur	33KV	Gajwel	20:30	Still			Lorry dashed to the pole	Lingapur	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Alwanpally	11KV	Jadcherla	02.20	09.20	07.00		11KV Jumper cut near Boyalakunta	No
1	NLG	Juloor	Kapraipally	11KV	Choutuppal	15:00	16:45	1:45	E/L	11KV Line snapped near Juloor (V)	No
1	SDPT	Pandilla	Kuchanapally	11KV	Husnabad	8:50	9:30	0:40		Breaker fault	No
1	RR N	Jagathgiringutta	Jagathgiringutta	11KV	Medchal	13:15	15:00	1:45		11KV AB Cable Failed at Anjaiah Nagar (Line AB Switch opened at Road No 5,Anjaiah Nagar)	No
2		Aliabad	Bommarajpet	11KV	Medchal	16.42	18.10	01.28		Lizard fallen on 11KV Line at Ramalayam Temple	No
3		GP Pally	GP Pally	11KV	Medchal	16.20	19.30	03.10		11KV Conductor Snapped and replaced Aparna Gate	No