

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	4	0	4	0	4	0	0	
	Grand Total	1082	6468	0	10	0	10	0	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.02.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
NIL												

TSSPDCL - LMRC / Corporate office

Date: 11.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Maddur	Pedripad	11KV	Narayanapet	15.50	17.10	01.20		Due to LT /11 KV phase to phase at Pedripad agl	No
2		Pallerla	Nandipad	11KV	Narayanapet	07.45	11.02	03.17		Break Down due to 11KV line cut at pallerla vg	No
1	NLG	Nuthankal	Yadavalli	11KV	Suryapet	8:05	10:46	2:41	E/L	Insulator failed	No
1	SDPT	Kodakandla	Kodakandla Agl	11KV	Gajwel	5:55	13:58	8:03		Pole Damage	No
1	RR N	Kandlakoya	Saigeetha Ashramam	11KV	Medchal	14:40	17:23	2:43		Tree Fallen on 11KV Line at PTC Kandlakoya	No
2		Subhash Nagar	Suchitra	11KV	Medchal	12.35	13.30	00.55		CT Problem in SS(Backfeeding arranged from 11KV Ramraj Nagar feeder)3484.39	No
3		Subhash Nagar	Jairam Nagar	11KV	Medchal	15.53	17.10	01.17		No fault	No
4		Kompally	NCL	11KV	Medchal	17.20	17.50	00.30		11KV Jumper cut and replaced at NCL North	No
1	RR E	Saketh	Dammaiguda	11KV	Keesara	5:06	6:15	1:09		Line Patrolling but no visible fault	No
1	HYD N	I.D.P.L	Wonder Plast	11KV	VI	02.15	04.05	01.50	EL	Lizard fallen on DTR at SVCIE Canteen (2 No. HT Services kept off)	No