

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988	1	4	1	4	1	4			
3	MDK	107	933		1		1		1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	10	1	10	1	10	0	0	
	Grand Total	1082	6468	1	13	1	13	1	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.02.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Miryalguda	Tripuraeram	33KV	Miryalguda	08.10	13.20	05.10	E/L	Tree Fallen On the 33Kv Line and Bird Fallen on line at srinivas Nagar		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 13.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Sarjakhpet	Pothireddypally	11KV	Narayanapet	10.20	11.24	01.04		Break Down due to 11KV conductor snapped and cut at Pothireddypally vg	-
2		Mohammadabad	Shaikpally	11KV	Narayanapet	15.04	15.50	00.46		Break Down due to 11KV conductor snapped and cutat Mukkarlabad vg	-
3		MOGALMADKA	MOGALMADKA RURAL	11KV	Narayanapet	06.20	08.30	02.10		BREAKDOWN DUE TO 11KV LINE CUT,	-
4		PERAPALLA	SHASHANPALLY	11KV	Narayanapet	11.05	12.10	01.05		BREAKDOWN DUE TO TREE BRANCH FALLEN ON LINE, HANUMAN TEMPLE, SHASHANPALLY	-
1	NLG	Akaram	Shanthi Nagar	11KV	Nalgonda	11.10	12.20	01.10	E/L	11Kv Insulator failed	-
2		Munagala	Nelamarry	11KV	Huzurnagar	05.00	07.15	02.15	E/L	11Kv Line Snapped	-
3		Maryala	Mailaram	11KV	Bhongir	10.50	13.12	02.22	E/L	11Kv Line snapped near Medipally (V)	-
4		Choutuppal	Chinnakondur	11KV	Choutuppal	09.20	11.25	02.05	E/L	11Kv Line snapped near Choutuppal town	-
1	MDK	EPIP-III	Tyechi Diecast Feeder	11KV	Sangareddy	17.15	17.42	00.27		BD due to Insulator failed	-
1	SDPT	Chowdaram	Yellammajal	11KV	SIDDIPET	09.35	14.09	04.34		B/W LT/11KV lc.no 17163	-
1	RR N	HMT	Ganesh Nagar	11KV	Medchal	09.55	10.45	00.50	BD	Tree Branch fallen on the 11KV Line at Cherukupally Colony	-
2		HMT	Ganesh Nagar	11KV	Medchal	14.40	15.25	00.45	BD	Tree Branch fallen on the 11KV Pole at Cherukupally Colony	-
1	RR E	Ramanthapur	Venkatreddy nagar	11KV	Habsiguda	14.18	16.10	01.52		11KV line snapped at Keerti Bhadra appt & line AB switch open & load added from Ps colony feeder	-