

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		3		3		3			
3	MDK	107	933		1		1		1			
4	SDPT			1	4	1	4	1	4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	8	2	8	2	8	0	0	
	Grand Total	1082	6468	2	11	2	11	2	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.02.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mariakl	Devarkadra	33KV	Narayanapet	08.25	11.10	02.45	E/L	Jumper Replacement at Khila Gate	Devarkadra	Alternate Supply Arranged to 33KV Koukontla Feeder at 11:10 hrs
1	SDPT	Thunkibollaram	Markook	33KV	Gajwel	10:26	14:50	4:24		Cable kit problem	Markook	132/33 KV Gajwel From 33 KV Mulugu Feeder at 14:50 hrs.

TSSPDCL - LMRC / Corporate office

Date: 15.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pendlipakala	Gajinagar	11KV	Devarakonda	14:00	15:30	1:30	EL	11 Kv Jumper Cutt	No
2		Ravulapally	Manapuram	11KV	Suryapet	07.25	10.00	02.35	EL	Insulator failed	No
3		Mothkur	Kondagadapa	11KV	Bhongir	09.30	11.00	01.30	EL	11kv Line Snapped	No
1	MDK	Kistareddypet	Industrial	11KV	Patancheru	5:15	5:50	0:35		Jumper cut	No
1	SDPT	Machapur	Machapur	11KV	Siddipet	11:10	15:51	4:41		B/D for OL Tripping LC No.11039	No
2		MULUGU	BAILAMPUR	11KV	Gajwel	16.30	13.15	20.45		11KV WIRES ARE TANGLED YESYERDAY	No
3		MD SHAPUR	INDUSTRIAL	11KV	Gajwel	12.20	14.20	02.00		11KVA HT/ LT	No
4		Nagapuri	Pothireddypally	11KV	Husnabad	00.00	07.35	07.35		Insulator failed	No
1	RR N	Medchal	Victory	11KV	Medchal	10:40	13:00	2:20		CT failed in SS(Backfeeing arranged from IDA-II Feeder)	No
2		GP Pally	Apparel Park	11KV	Medchal	19.15	20.05	00.50		11KV Jumper cut and replaced at Apparel Park	No
1	HYD N	Macha Bollaram	Radha Sath Sang	11KV	C-VI	17.40	18.50	01.10	A/R opened	Bird fault on DTR at Radha Sath Sang	No