

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	7	0	7	0	7	0	0	
	Grand Total	1082	6468	0	7	0	7	0	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.02.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	mbnr				nil							-
2	nlg				nil							-
3	mdk				nil							-
4	sdpt				nil							-
5	rr south				nil							-
6	rr north				nil							-
7	rr east				nil							-
8	hyd				nil							-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 16.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Vennached	Lingaipally		Narayanapet	07.55	08.35	00.40		11KV conductor snapped and cut at Near Jinnaram vg	-
2		KANKURTHY	KANUKURTHY		Narayanapet	12.40	14.30	01.50		DISC FAILURE, SUPPLY RESTORED FROM ANOTHER FEEDER	-
1	NLG	Athmakur(S)	Athmakur Agl		Suryapet	12.26	14.50	02.24	E/L	Insulator failed	-
2		Gondiryala	Gondiryala-2		Huzurnagar	05.00	08.15	03.15	EL	11 KV LINE SNAPPED	-
1	SDPT	THIGUL	THIGUL AGL		Gajwel	13.14	14.40	01.26		TREE BRANCH FALL OVER 11KV	-
2		GOWRARAM	PATHUR		Gajwel	09.30	11.00	01.30		INSULATOR FAILED	-
3		DOULTHABAD	LINGARAJPALLY		Gajwel	11.09	12.10	01.01		11KV HT/LT line fault	-