

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT			1	7	1	7	1	7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	10	1	10	1	10	0	0	
	Grand Total	1082	6468	1	12	1	12	1	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.02.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDP	Angadikistapur	Ganeshpally	33KV	Gajwel	11.36	12.10	00.34		Earth falt (Over Current)	Ganeshpally	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 18.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Palem	Ogodu	11KV	Nalgonda	04.05	09.00	04.55	EL	11KV Jumper cut	-
2		Koppole	Bheemaram	11KV	Nalgonda	12.10	17.00	04.50	EL	11KV Jumper cut	-
3		Golankonda	Golankonda	11KV	Bhongir	11.45	13.10	01.25	EL	11kv line sanpped	-
1	SDP	Jagdevpur SS	Jagdevpur Town Feeder LC.No.5712	11KV	Gajwel	09.05	11.15	02.10		Insulator fail	-
2		Pregnapur	Gundannapally AGL LC.No.1993	11KV	Gajwel	10.40	12.47	02.07		Treebranches has fallen	-
3		Vantimaidi SS	RR colony feeder LC.No.24424	11KV	Gajwel	10.05	11.05	01.00		Jumper cut	-
4		Medinipur SS	Mathpally Feeder LC.No.171	11KV	Gajwel	09.50	12.50	03.00		Disk fail	-
5		Nagapuri	Nagapuri	11KV	Husnabad	03.45	09.45	06.00		Line Cut	-
6		Husnabad-I	Town-I	11KV	Husnabad	13.10	13.30	00.20		11KV Line Cut	-
7		Ramachandrapur	Vinjalpally	11KV	Husnabad	15.30	16.30	01.00		11KV Line Cut & Insulator fail	-
1	RR N	Kompally	Nuziveedu Seeds	11KV	Medchal	08.25	09.00	00.35	BD	11KV Line AB Switch Opened at Royal Park(Jumper Phase to Phase)	-
1	RR E	Balaji Nagar	Laxmi Narsimha	11KV	Habsiguda	10.00	11.23	01.23		11KV Pole damaged due to Trolley dashed at Renuka Nagar	-