

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		4		4		4			
6	RR(N)	54	550	2	15	2	15	2	15			
7	RR(E)	168	403		33		33		33			
8	Hyd	194	1044		46		46		46			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>2</b>	<b>98</b>	<b>2</b>	<b>98</b>	<b>2</b>	<b>98</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		1		1		1			
3	MDK	107	933	3	1	3	1	3	1			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>4</b>	<b>6</b>	<b>4</b>	<b>6</b>	<b>4</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>6</b>	<b>104</b>	<b>6</b>	<b>104</b>	<b>6</b>	<b>104</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 19.02.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Achampet	Kondanagula	33KV	Nagarkurnool	14.53	15.30	00.37		Kondareddypally isolator opened supply stood OK	Kondanagula	No
1	MDK	R.C.Puram	NSL	33KV	Patancheru	3:51	9:45	5:54		Jumper cut	NSL	No
2		Gummadidala	Dundigal	33KV	Patancheru	14.30	16.15	01.45		Jumper cut	Dundigal	No
3		Zaheerabad	Hadnoor	33KV	Zaheerabad	11.00	16.40	05.40		Jumper cut	Hadnoor	No
1	RR N	132KV Medchal	Athiwelly	33KV	Medchal	15:48	17:45	1:57		Tripped on EL Indication (Due to Rain )	Athiwelly	No
2		132KV Medchal	Kandlakoya	33KV	Medchal	16.15	18.25	02.10		33KV Pin Insulator failed at Kandlakoya	Kandlakoya	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kondapur	Chandapur	11KV	Narayanpet	05.00	07.30	02.30		Jumper cut & fallen on Cross Arm	No
1	NLG	Bibinagar	Hindusthan	11KV	Bhongir	0:30	9:30	9:00	EL/OL	11 kv Pin insulator failed & 11 kv Line snapped at Manne paper company near Bramhanapally village.	No
1	MDK	Bonthapally	Veerabadra	11KV	Patancheru	0:05	3:15	3:10		Conductor snapped	No
1	SDPT	Ramancha	Ramancha	11KV	Siddipet	0:00	8:00	8:00		Disc failed	No
2		Chittapur	Chowdarpally	11KV	Siddipet	10.30	13.40	03.10		Disc failed	No
3		Gajwel&pregnapur	Houseing bord colony	11KV	Gajwel	23.49	00.40	00.51		Jumper cut	No
1	RR S	IIIT	APHB Colony	11KV	Gachibowli	0:46	2:28	1:42		11KV Line AB Switch opened near Dog Park at APHB Colony.	No
2		IIIT	Hockey Stadium	11KV	Gachibowli	03.05	04.20	01.15		O/G 11KV AB Switch opened at SS	Backfeeding from 11kv IVRCL Feeder.
3		Kothaguda	Izzath Nagar	11KV	Kondapur	06.05	07.05	01.00		11KV AB Cable Failed at Izzath Nagar.	No
4		Borabanda	Padmavathi Nagar	11KV	Kondapur	16.10	17.25	01.15		11KV Disc Failure and Replacement at RK Society Dargah.	No
1	RR N	Balajinagar	Kukatpally	11KV	Kukatpally	16:14	17:25	1:11	EL/OL	11kv LABS open at royal Wood Furniture	No
2		Madinaguda	Widio Colony	11KV	Kukatpally	00.22	01.22	01.00	EL/OL	11kv Pin Insultor failure At Allwyn X Road	No
3		Bowrampet	Bowrampet Village	11KV	Jeedimetla	14.55	16.12	01.17	EL	11kv Pin Insultor Failure At Praneeth	No
4		Jagathgirigutta	Shiridi Hills	11KV	Medchal	16.25	17.55	01.30	EL	11KV Cable endkit failed at Somaiah Nagar	Back feeding Arranged from 11KV maqdoom nagar feeder
5		Aliabad	LGM Pet	11KV	Medchal	03.00	05.00	02.00		11KV Conductor Snapped at LGM Pet Village	No
6		Uddamarry	Usharpally	11KV	Medchal	04.00	06.00	02.00		11KV Pin Insulator failed and replaced Usharpally Bus stop	No
7		Aliabad	Majeedpur	11KV	Medchal	16.25	16.38	00.13		11KV Line AB Switch Opened at Aliabad X Road	No
8		Gowdavelly	Gowdavelly	11KV	Medchal	15.40	16.50	01.10		11KV Line cut at Gowdawelly Village	No
9		GP Pally	APIIC	11KV	Medchal	16.50	17.40	00.50		11KV Pin Insulator failed at Apparel Park	No
10		Devarayamjal	DMC	11KV	Medchal	16.00	18.35	02.35		Tree fallen on 11KV Line at Mallanna Colony	No
11		Medchal	Check Post	11KV	Medchal	16.10	18.00	01.50		11KV Pin Insulator failed at Medchal Check post	No