

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		8		8		8			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	12	0	12	0	12	0	0	
	Grand Total	1082	6468	0	17	0	17	0	17	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.02.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	RR S				NIL							-
5	RR N				NIL							-
6	RR E				NIL							-
7	HYD				NIL							-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 20.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	MARIKAL	PC KUNTA	11KV	NARAYANPET	12.20	13.40	01.20		BREAKDOWN DUE TO 11KV LINE CUT	-
1	NLG	Ch.Annaram	Chervuannaram	11KV	Nalgonda	12.30	15.15	02.45	EL	11 KV Insulator Failed	-
2		Pamanagundla	Ismailpally	11KV	Nalgonda	12.33	14.30	01.57	EL	11 KV Jumper Cut	-
3		Penpahad	S.R.Palem	11KV	Suryapet	07.00	10.45	03.45	EL	Insulator failed	-
4		Keethavarigudem	Velidanda	11KV	Huzurnagar	10.40	12.50	02.10	EL	11 KV LINE SNAPPED	-
5		B.Ramaram	Saiteja Indl	11KV	Bhongir	00.05	08.15	08.10	EL/OL	11 kv Line snapped near Thirumalagiri village	-
6		Sharajipet	Sharajipet	11KV	Bhongir	11.50	13.50	02.00	EL/OL	11kv Line snapped near Sharajipet Village	-
7		Azeempet	Repaka	11KV	Bhongir	11.53	15.30	03.37	EL/OL	11kv Line Snapped near Repaka Village	-
8		Varkatpally	Gokaram	11KV	Choutuppal	11.35	12.00	00.25	EL/OL	100kva DTR Failed near Gokaram Village	-
1	SDPT	Pedda Cheekode	ArePally	11KV	Siddipet	14.25	15.15	00.50		Tree Branch Fallen On 11 Kv Line	-
2		DOMMAT	DOMMAT	11KV	Gajwel	1:40	7:40	6:00		1 PH DTR FAILED	-
3		AKKANNAPET	AKKANNAPET RURAL	11KV	Husnabad	02.24	02.24	00.00		BD DUE TO 11 KV JUMPER CUT	-
1	RR N	Dp Pally -II	Cable M L R	11KV	Jeedimetla	02.20	05.10	02.50		11kv Conductor Snapped At Medchal Road	-
2		Athiwelly	Ravalkole thanda	11KV	Medchal	00.00	00.55	00.55		11KV Line cut near Shantha biotech company	-
3		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	15.10	16.55	01.45		100KVA T/F AB Switch Opened at Baisaki Dhabha(1 No DTR in off)	-
4		ICICI	Bharath Biotech	11KV	Medchal	16.45	18.05	01.20		11KV Jumper cut and replaced at Zeno Tech Company	-
1	RR E	Moula ali	Malkajgiri	11KV	Habsiguda	14.19	15.08	00.49		Bird fallen on 11Kv line at Dr Krishna Nagar	-