

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		6		6		6			
2	NLG	144	988	1	4	1	4	1	4			
3	MDK	107	933		0		0		0			
4	SDPT			1	2	1	2	1	2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>12</b>	<b>2</b>	<b>12</b>	<b>2</b>	<b>12</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>15</b>	<b>2</b>	<b>15</b>	<b>2</b>	<b>15</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 24.02.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Wadapally	A.D.Pally	33KV	Miryalaguda	08.15	09.10	00.55	EL	Jumper Cut		-
1	SDPT	Husnabad	Katkur	33KV	Husnabad	13.40	16.15	02.35		BD( Line Combined near Husnabad Court)		-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 24.02.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mohammadabad	V.R Pally	11KV	Narayanapet	07.49	12.15	04.26		Break down due to Jumper cut at Bhumikunta vg	-
2		Nancherla	Nancherla	11KV	Narayanapet	15.47	16.50	01.03		Break down due to phase to phase Mangampet vg	-
3		Venneched	Lingaipally	11KV	Narayanapet	07.18	07.45	00.27		Break Down due to bird fallen on 11KV line at Lingaipally vg	-
4		Manthangoud	MATHANGODE	11KV	Narayanapet	15.40	16.00	00.20		Break Down due to bird fallen on 11KV line near SS	-
5		Jaklair	JAKLAIR	11KV	Narayanapet	09.28	10.45	01.17		Break Down due to 11Kv cond cut at jaklair	-
6		KANKURTHY	DAMARGIDDA	11KV	Narayanapet	07.50	09.41	01.51		Break Down due to 11kv line cut,	-
1	NLG	Shaligouraram	Gurajala	11KV	Nalgonda	10.00	11.10	01.10	EL	Insulator failed	-
2		D Nagaram	D Nagaram	11KV	Suryapet	05.00	08.15	03.15	EL	Insulator failed	-
3		Repala	Repala	11KV	Huzurnagar	04.15	07.15	03.00	EL	11 KV LINE SNAPPED	-
4		Gurraladandi	Indl	11KV	Bhongir	08.00	10.00	02.00	EL/O/L	11kv Line snapped near Kiishna Raic mail	-
1	SDPT	Mustabad X Road	Nagadevath X Road	11KV	Siddipet	13.45	14.05	00.20		B/D Insulator Damage	-
2		VARDARAJPUR	SHIVARVENKATAPUR(LC.NO:514) LAXMAN.LM	11KV	Gajwel	9:25	11:19	01.54		11 KV LINE CUT	-
1	RR N	Kandlakoya	Kandlakoya	11KV	Medchal	14.40	17.06	02.26	BD	11KV Pole damaged by Lorry at Altra Tech Company	-
1	RR E	Moula-Ali	Spectra	11KV	Sainikpuri	07.34	08.32	00.58		11Kv Pin Insulator failed at Industrial Area (Artisan Raju)	-
1	HYD N	Prashanth Nagar	Shakthipuram	33KV	Bowenpally	16.50	18.47	01.57	EL	Cable Fault	Arranged B/F on 11KV Sony Complex fdr