

**Status Report on Breakdowns (Urban / Rural)****Urban**

| S.No | Circle       | No.of Feeders Existing Urban |             | Breakdowns occurred during the day |          | Attended during the day |          | Time taken for restoring the supply |          |                                |          | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
|      |              | 33KV                         | 11KV        | 33KV                               | 11KV     | 33KV                    | 11KV     | Rectified (Within 24 Hours)         |          | Not Rectified (Above 24 Hours) |          |                   |
|      |              |                              |             |                                    |          |                         |          | 33KV                                | 11KV     | 33KV                           | 11KV     |                   |
| 1    | MBN          | 18                           | 107         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 2    | NLG          | 22                           | 358         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 3    | MDK          | 97                           | 359         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 4    | SDPT         |                              |             |                                    |          |                         |          |                                     |          |                                |          |                   |
| 5    | RR(S)        | 53                           | 234         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 6    | RR(N)        | 54                           | 550         |                                    | 1        |                         | 1        |                                     | 1        |                                |          |                   |
| 7    | RR(E)        | 168                          | 403         |                                    |          |                         |          |                                     |          |                                |          |                   |
| 8    | Hyd          | 194                          | 1044        |                                    | 2        |                         | 2        |                                     | 2        |                                |          |                   |
|      | <b>Total</b> | <b>606</b>                   | <b>3055</b> | <b>0</b>                           | <b>3</b> | <b>0</b>                | <b>3</b> | <b>0</b>                            | <b>3</b> | <b>0</b>                       | <b>0</b> |                   |

**Rural**

| S.No | Circle             | No.of Feeders Existing Rurals |             | Breakdowns occurred during the day |           | Attended during the day |           | Time taken for restoring the supply |           |                                |          | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
|      |                    | 33KV                          | 11KV        | 33KV                               | 11KV      | 33KV                    | 11KV      | Rectified (Within 24 Hours)         |           | Not Rectified (Above 24 Hours) |          |                   |
|      |                    |                               |             |                                    |           |                         |           | 33KV                                | 11KV      | 33KV                           | 11KV     |                   |
| 1    | MBN                | 107                           | 849         | 1                                  |           | 1                       |           | 1                                   |           |                                |          |                   |
| 2    | NLG                | 144                           | 988         |                                    | 2         |                         | 2         |                                     | 2         |                                |          |                   |
| 3    | MDK                | 107                           | 933         |                                    | 2         |                         | 2         |                                     | 2         |                                |          |                   |
| 4    | SDPT               |                               |             | 1                                  | 6         | 1                       | 6         | 1                                   | 6         |                                |          |                   |
| 5    | RR(S)              | 58                            | 396         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 6    | RR(N)              | 38                            | 114         |                                    |           |                         |           |                                     |           |                                |          |                   |
| 7    | RR(E)              | 22                            | 133         |                                    |           |                         |           |                                     |           |                                |          |                   |
|      | <b>Total</b>       | <b>476</b>                    | <b>3413</b> | <b>2</b>                           | <b>10</b> | <b>2</b>                | <b>10</b> | <b>2</b>                            | <b>10</b> | <b>0</b>                       | <b>0</b> |                   |
|      | <b>Grand Total</b> | <b>1082</b>                   | <b>6468</b> | <b>2</b>                           | <b>13</b> | <b>2</b>                | <b>13</b> | <b>2</b>                            | <b>13</b> | <b>0</b>                       | <b>0</b> |                   |

TSSPDCL - LMRC / Corporate office

Date: 28.02.2021

Circle-wise 33KV Breakdowns

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown                                   | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|---------------------------|
| 1    | MBNR   | Achampet            | Inole                | 33KV | Nagarkurnool         | 14.10 | 19.50 | 05.40    | E/L              | Tree Branch Fallen on the line near Rangapur Pyramid | Inole                 | -                         |
| 1    | SDPT   | HABSIPUR            | Pothareddypet        | 33KV | SDPT                 | 04.48 | 04.48 | 02.00    |                  | B/D due to to bird fallen on line                    | Pothareddypet         | -                         |

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 28.02.2021

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown   | Alternate Supply Arranged                     |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---|
| 1    | NLG    | Eduloor            | Eduloor              | 11KV | Nalgonda             | 08.00 | 10.00 | 02.00    | EL               | 11 KV Jumper Cut at SS-5   | -   |
| 2    |        | Kudakuda           | Komatikunta          | 11KV | Suryapet             | 04.00 | 07.25 | 03.25    | EL               | Insulator failed   | -   |
| 1    | MDK    | Sangareddy Town-I  | Collector Feeder     | 11KV | Sangareddy           | 10.50 | 15.10 | 04.20    |                  | B/D due to Tree branches fallen on the line                            | -   |
| 2    |        | Bollaram-I         | Town-I               | 11KV | Patancheru           | 14.20 | 17.15 | 02.55    |                  | B/D due to Conductor snapped   | -   |
| 1    | SDPT   | DUDEEDA            | CHELAMPU             | 11KV | Gajwel               | 13.00 | 14.10 | 01.10    |                  | TREE BRANCH FALL OVER 11 KV LINE                                       | -   |
| 2    | SDPT   | GURRALASOPA        | WADDEPALLY           | 11KV | Gajwel               | 14.45 | 17.20 | 02.35    |                  | JUMPER CUT   | -   |
| 3    | SDPT   | MULUGU             | NARSAMPALLI          | 11KV | Gajwel               | 11.00 | 11.50 | 00.50    |                  | 100KVA DTR FAILED  | -   |
| 4    | SDPT   | Dubbak             | Chervapur            | 11KV | SDPT                 | 16.45 | 18.20 | 01.35    |                  | B/D-11KV wire cut-Now rectified  | -   |
| 5    | SDPT   | Thadkapally        | Thadkapally          | 11KV |                      | SDPT  | 13.02 | 14.48    | 01.46            |  | B/D-Tree bunches fallen on line-Now rectified |
| 6    | SDPT   | Mustyal            | Chuchanakota         | 11KV | Husnabad             | 03.36 | 07.12 | 03.36    |                  | B.D, DUE TO LINE CUT   | -   |
| 1    | RR N   | Jagathgirigutta    | IDA                  | 11KV | Medchal              | 09.45 | 11.20 | 01.35    | BD               | 2 Nos. AB Cable End Kit failed at Papi Reddy Nagar & Hari OM Show Room | -   |
| 1    | HYD C  | Vittalwadi         | Basanth Colony       | 11KV | II                   | 08.30 | 09.35 | 01.05    | EL               | Cable fault  |   |
| 2    |        | Chilkaiguda        | Golconda X Road      | 11KV | II                   | 14.10 | 15.45 | 01.35    | EL               | Foreign material fallen on Lines & HG fuse B/O at Golconda X Road      |   |