

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	1	1	1	1	1			
7	RR(E)	168	403									
8	Hyd	194	1044	1		1		1				
	Total	606	3055	2	1	2	1	2	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	2	0	2	0	2	0	0	
	Grand Total	1082	6468	2	3	2	3	2	3	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.01.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	LGM Pet	33KV	Medchal	3:45	5:15	1:30		No visible fault	LGM Pet	No
1	HYD N	132KV Balkampet	Allwyn	33KV	Allwyn	03.53	13.00	09.07		33kv Allwn feeder tripped on OL due to car hit the pole opposite to voltas company at sanathnagar (after newpole erection loads normalised) Regular & alternate supply same pole.	Allwyn	No

TSSPDCL - LMRC / Corporate office

Date: 02.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Jalalpuram	Siddi Samudram	11KV	Suryapet	12:40	14:58	2:18	E/L	Insulator failed	No
2		Munagala	Thadvai	11KV	Huzurnagar	12.45	14.05	01.20	E/L	11KV Line snapped	No
1	RR N	Kistapur	Kistapur	11KV	Medchal	6:35	7:45	1:10		11KV Conductor snapped and replaced at Weaker section Colony	No