

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT			2	1	2	1	2	1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	4	2	4	2	4	0	0	
	Grand Total	1082	6468	2	4	2	4	2	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 03.12.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Husnabad	Thotapally	33kv	Husnabad	01.00	13.05	12.05		Line problem	Thotapally	Katkur 23:40
2		Husnabad	Katkoor	33kv	Husnabad	13.30	14.50	01.20		Line problem	Katkoor	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 03.12.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kistrampally	M.M.Pally	11kv	Devarakonda	12.05	12.55	00.50	EL	11 KV Jumper Cutt	-
2		Datherpally	Mallapuram	11kv	Bhongir	07.05	09.40	02.35	EL/OL	11 kv Insulator failed near Mallapuram village.	-
3		Juloor	Pilaipally	11kv	Choutuppal	08.42	10.45	02.03	EL/OL	11 kv Line snapped at Pakkeru. Lachireddy well near pilaipally village	-
1	SDPT	Nagapuri	Shabashgudem	11kv	Husnabad	08.30	10.25	01.55		B/d due to Line cut	-