

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		1		1		1			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	2	1	2	1	2	0	0	
	Grand Total	1082	6468	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 04.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Bollaram	Shathavahana	33KV	Patancheru	19.40	20.35	00.55		B/D due to Tree branches fallen on the line		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 04.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kondapur	Charlapally	11KV	Narayanpet	08.10	09.32	01.22		Due to Squarrel Fallen on the Line Near Cherlapally(V)	-
1	NLG	Velugupally	Pasnooru	11KV	Suryapet	03.40	07.05	03.25	E/L	Tree branch fallen and 11Kv Conductor snapped	-
1	RR N	Kandlakoya	Saigeetha Ashramam	11KV	Medchal	10.45	11.40	00.55	BD	11KV Pole damaged at Suman Steel Company	-
2		Athiwelly	PHI	11KV	Medchal	12.20	13.20	01.00	BD	11KV Line Cut & Replaced at Rekula Bhavi	-
3		ICICI	Bharath Biotech	11KV	Medchal	15.35	17.20	01.45	BD	11KV Pole damaged by Lorry at Saibaba Temple	-
1	HYD N	Pragatools	Indo Swing	11KV	VI	02.33	03.50	01.17	EL,OL-Rph	UG Cable fault at Gandhi Nagar	-
2		Tirumalagiri	Officers Colony	11KV	C-VI	11.45	12.50	01.05	Tripped AR	Sectionlizer fault at Military Hospital	Arranged B/F on 11KV Naga Devatha fdr