

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988	2	1	2	1	2	1			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	3	3	3	3	3	0	0	
	Grand Total	1082	6468	3	4	3	4	3	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 08.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Oil Seeds	33KV	Gadwal	03.35	08.45	05.10	EL	Pin Insulator Replaced Near Jammichedu(V)		NO
1	NLG	Suryapet	Nuthankal	33KV	Suryapet	06.10	09.30	03.20	E/L	33Kv Jumper cut		-
2		Suryapet	Yerkaram	33KV	Suryapet	06.40	10.30	03.50	E/L	33Kv Jumper cut		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 08.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mustipally	11KV SATYARAM FEEDER	11KV	Narayanapet	07.26	08.53	01.27		11KV Conductor Cut and fallen on 25KVA DTR at Mustipally vlg	-
2		KOTAKONDA	BANDAGONDA	11KV	Narayanapet	03.50	06.36	02.46		JUMPER CUT AND FALLEN ON CROSS ARM, GANIMONI BANDA	-
1	NLG	N.Annaram	Dosapahad	11KV	Suryapet	11.15	14.20	03.05	E/L	11Kv Conductor snapped	-
1	HYD S	Malakpet	Bibi Ka Alwa	11KV	VIII	15.15	18.22	03.07	EL,OL	Cable fault at Azampura Nala	Arranged B/F on 11KV Yakuthpura fdr