

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	0	7	0	7	0	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	SDPT				NIL							-
5	RR S				NIL							-
6	RR N				NIL							-
7	RR E				NIL							-
8	HYD				NIL							-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 11.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Salkarpet	Thalapur	11KV	Narayanapet	05.20	10.20	05.00		Due to Squarrel Fallen on the 11 KV line	-
2		Vennached	Janampally	11KV	Narayanapet	07.45	11.50	04.05		Due to 11KV Disc failed	-
1	NLG	MT.Pally	Dathaipally	11KV	Bhongir	03.30	09.28	05.58	EL	11kv Line Snapped near Dathaipally Village	-
1	SDPT	Nangnoor	Nagarajupally	11KV	Siddipet	02.35	10.45	08.10		B/D-Due to Bird	-
2		Chittapur	Mothye	11KV	Siddipet	12.44	12.51	00.07		B/D Tree brach fall in 11 KV line	-
3		VANTIMAMIDI	INDUSTRIAL	11KV	Gajwel	09.35	10.15	00.40		CONDUCTOR SNNAPED	-
1	HYD S	Seetharambagh	Seetharambagh	11KV	IX	08.40	09.50	01.10	EL,OL	Conductor snapped at Kishti Chaman	(09:10 Hrs partial fdr charged)