

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3		2		2			
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT				2		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 12.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	SDPT				NIL							-
5	RR S				NIL							-
6	RR N				NIL							-
7	RR E				NIL							-
8	HYD				NIL							-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 12.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Paspula	Mushtipally	11KV	Naraynpet	18.00	18.20	00.20		Due to Bird Fallen on 11KV line at Muslaipally	-
2		Paspula	Satyaram	11KV	Naraynpet	05.00	06.40	01.40		Due to Tree Branch Fallen on 11KV line at panchalingal (V)	-
3		Marikal	PC Kunta	11KV	Naraynpet	12.10	15.05	02.55		Due to 11KV Jumper Cut at Dharma Kunta Cheruvu, Venkatapur Road	-
1	NLG	D Nagaram	Machireddypally	11KV	Suryapet	06.00	09.05	03.05	E/L	11Kv Jumper cut	-
1	SDPT	Thotapally	Mallampally	11KV	Husnabad	09.50	11.30	01.40		Line cut	-
2		Chityal	Chityal	11KV	Husnabad	14.40	15.05	00.25		Line problem	-
1	RR N	Subhash Nagar	Padma Nagar	11KV	Medchal	18.08	19.12	01.04		11KV Jumper cut at Venkateshwara colony	-