

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT				8		8		8			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	9	0	9	0	9	0	0	
	Grand Total	1082	6468	0	15	0	15	0	15	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.01.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
NIL												

TSSPDCL - LMRC / Corporate office

Date: 14.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cheedella	Express	11KV	Suryapet	14:40	16:30	1:50	E/L	Conductor snapped	No
1	SDPT	Markook SS	Markook AGL	11KV	Gajwel	3:25	8:00	4:35		11 KV line cut	No
2		Pamulapoorthy SS	Indiranagara	11KV	Gajwel	09.40	10.25	00.45		11 KV line cut	No
3		Pamulapoorthy SS	Ippalagudem	11KV	Gajwel	11.30	12.00	00.30		DTR Failed	No
4		Pamulapoorthy SS	Ippalagudem	11KV	Gajwel	13.05	14.05	01.00		DTR Failed	No
5		Marpadaga SS	Marpadga AGL	11KV	Gajwel	17.30	17.55	00.25		DTR Insulator failed	No
6		Raipole SS	Roipole AGL	11KV	Gajwel	17.00	18.10	01.10		Coper Patty Cut	No
7		Laxmidevipally	Laxmidevipally	11KV	Siddipet	00.00	08.40	08.40		B/D Stay wire Touching Lt line Lc.no11394	No
8		Habshipur	Dharmaram	11KV	Siddipet	19:04	21:28	2:24		Break Down Insulater faillure	No
1	RR N	Jagathgirigutta	Shiridi Hills	11KV	Medchal	12:45	14:15	1:30	EL	11KV Line AB Switch Opened at Road No:6,Anjaiah Nagar (No Fault)	No
2		DP Pally	AGL Gagillapur	11KV	Jeedimetla	10.00	11.00	01.00	OL	Kite Fallen on the 11kv line at Outer Ring Road	No
1	HYD N	Seethaphal Mandi	Seethaphal Mandi	11KV	V	12.55	14.00	01.05	EL	Auto Reclosure fault near SS	No
2		Gymkhana	Picket	11KV	C-VI	17:45	19:00	1:15	EL,OL-Bph	DTR fault at Srinivasa Colony	No
1	HYD C	Gudimalkapur	Sri Ram Nagar	11KV	VII	14.35	15.44	01.09	EL,OL	No Visible Fault	Arranged B/F on 11KV Jeevan Kalyan Nagar feeder
2		Golnaka	Sai Madhura Nagar	11KV	II	16.53	18.18	01.25	EL,OL	HT Line snapped at Ramalayam FOC	No