

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988		1		1		1			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>1</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>1</b>	<b>9</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 15.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Narayankhed	Kalheer	33KV	Jogipet	11.30	17.00	05.30		B/D due to Insulator failed	Kalheer	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 15.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Pallerla	Parsapur	11kv	Narayanpet	15.20	15.50	00.30		11KV Conductor cut at Parsapur village	-
2		Gudeballore	CHECKPOST	11kv	Narayanpet	09.30	10.45	01.15		11KV Conductor cut near checkpost	-
3		KANUKURTHY	KANUKURTHY	11kv	Narayanpet	08.10	10.30	02.20		BREAKER PROBLEM, IN THE SUBSTATION	-
4		MARIKAL	MARIKAL TOWN	11kv	Narayanpet	15.05	16.30	01.25		JUMPER CUT, AT THREE LOCATIONS	-
1	NLG	MR.Gudem	Baswapuram	11kv	Bhongir	00.00	08.40	08.40	EL	11kv Insulator Failed near Baswapuram Village	-
1	MDK	Kistareddypet	Industrial	11kv	Patancheru	08.15	09.30	01.15		B/D due to Insulator failed	-
1	SDPT	Nagapuri	Pothireddipalli	11kv	Husnabad	14.40	17.50	03.10		Insulator Fail	-
1	HYD N	Gunrock	Anjaiah Nagar	11kv	VI	09.30	11.00	01.30	EL	Bird fault & Jumper cut at Road No.2, RTC Colony	-----
2	HYD C	Amberpet	6 Number X Road	11kv	II	06.20	08.00	01.40	EL,OL	AB Cable fault at Sri Ramana Theatre	Arranged B/F on 11KV Tulasi Nagar feeder