

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	5	1	5	1	5	0	0	
	Grand Total	1082	6468	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220/132KV SS Palkonda	Kodur	33KV	Mahabubnagar	07.25	10.58	03.33	EL	Tree branch follen on the line and Tree cutting	Kodur	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 17.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Eduloor	Parada	11KV	Nalgonda	02.20	07.30	05.10	EL	11KV Jumpr cut	-
2		Pamanagundla	Pittampally	11KV	Nalgonda	04.08	09.00	04.52	EL	11KV disc failed	-
3		Kudakuda	Komatikunta	11KV	Suryapet	10.55	11.45	00.50	EL	Jumper cut	-
4		Datherpally	Mallapuram	11KV	Bhongir	12.38	14.18	01.30	EL	11 kv Insulator failed	-
1	SDP	MULUGU	HORTICULTURE UNIVERSITY FEEDER	11KV	Gajwel	14.58	15.58	01.00		TREE BRANCH WAS FALLEN ON THE 11KV LINE	-
1	HYD S	Arundhathi Colony	Uppuguda	11KV	III	18.15	19.30	01.15	EL,OL	Cable failed at Mahankali Temple	-
1	HYD C	Hussain Sagar	Maruthi Nagar	11KV	I	14.45	16.42	01.57	EL,OL	Kite stick fallen on lines	-