

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	0	9	0	9	0	9	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 19.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Nacharam	11KV	Narayanapet	06.20	07.54	01.34		Due to Squarrel Fallen on 11KV line	-
2		Narayanapet	VIP Feeder	11KV	Narayanapet	09.20	09.45	00.25		Due to Kite Struck on the Line Near Shashanpally Road	-
1	NLG	Thungathurthy	Banda Ramaam	11KV	Suryapet	09.45	12.15	02.30	E/L	Insuiator failed	-
2		Golankonda	Mator	11KV	Bhongir	05.00	09.00	04.00	EL/OL	11kv Line Snapped near Golankonda Village	-
1	SDPT	MARKOOK	MARKOOK AGL	11KV	Gajwel	11.26	14.07	02.41		TIPPER PUNCHED THE POLE	-
1	RR N	Chintal	Bhagathsingh Nagar	11KV	Medchal	17.30	18.30	01.00	BD	Out going AB Switch sparked at SS	-
2		Gowdavelly	IDA Gowdavelly	11KV	Medchal	13.20	15.20	02.00	BD	11KV Pole Damaged by Lorry at Basaragadi	-
3		Gowdavelly	Basaragadi	11KV	Medchal	13.20	15.20	02.00	BD	11KV Pole Damaged by Lorry at Basaragadi	-
1	HYD S	Attapur	HUDA Colony	11KV	Charminar	23.40	01.50	02.10	EL,OL-Bph	Cable End Kit fault at HUDA Colony	-