

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		4		4		4			
3	MDK	107	933	1		1		1				
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	8	2	8	2	8	0	0	
	Grand Total	1082	6468	2	12	2	12	2	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Achampet	Amrabad	33KV	Nagarkurnool	15.27	21.05	05.38	E/L	Line Cut & Insulator Failed Near Munnanoor Residential School		NO
1	MDK	Sadasivpet	Koheer	33KV	Sangareddy	15.30	17.50	02.20		BD Due to line Mingled & Female Clamp Replaced		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 20.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kosgi	Mushrifa	11KV	Narayanapet	08.00	08.45	00.45		Due to Squarrel Fallen on the 11KV Line	-
2		Marikal	Eligandla	11KV	Narayanapet	11.18	12.40	01.22		Due to Bird Fallen on the Line Near Eligandla	-
1	NLG	Annaram	Samgem	11KV	Suryapet	10.40	12.30	01.50	E/L	11Kv Jumper cut	-
2		Nadigudem	Karvirala	11KV	Huzurnagar	12.25	14.00	01.35	E/L	11Kv Line Snapped	-
3		Siripuram	Srirangapuram	11KV	Huzurnagar	10.45	12.00	01.15	E/L	11Kv Jumper Cut	-
4		Puligilla	Kanchanapally	11KV	Choutuppal	11.40	14.50	03.10	EL/OL	11kv Line snapped near Kanchanapally (V)	-
1	SDPT	ANAJIPUR	ANAJIPUR	11KV	Gajwel	17.09	17.56	00.47		THE TREE BRANCHES BROKE & FELL ON THE 11KVA LINE	-
2		BEGUMPET	APPAIPALLY	11KV	Gajwel	12.15	18.11	05.56		HT/ LT CABLES ARE JOINT	-
1	RR N	Jeedimetla-II	NRSA	11KV	Jeedimetla	19.38	21.25	01.47	BD	Canttener Lory Touched the 11kv pole, & Phase to Phase line at 220kv Shapur back side	-
1	RR E	Nacharam	Nile	11KV	Habsiguda	13.04	14.10	01.06		11KV Nile feeder breaker CT Blast at SS Yard & B/F supply taken from 11KV Aura Feeder	-
1	HYD N	I.D.P.L.	S.V.C.I.E.	11KV	VI	10.35	11.40	01.05	EL,OL-Rph	Jumper cut at S.V.C.I.E., Bala Nagar	-
1	HYD S	Falaknuma	Chatrinaka	11KV	III	07.38	09.50	02.12	EL,OL-Rph	UG Cable fault at Boiguda	Arranged B/F on 11KV Police Quarters fdr