

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	14	2	1	2			
2	NLG	144	988		1		1		1			
3	MDK	107	933		1		1		1			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	6	14	6	1	6	0	0	
	Grand Total	1082	6468	1	8	14	8	1	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparth	Narsaipally	33KV	Wanaparth	11.56	14.18	02.22	EL	Re-Jumpering Near Anjanagiri Mitta	Narsaipally	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 23.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Jadcherla	Kodgal	11KV	Kodgal Agl	07.30	09.30	02.00		11KV Jumper cut near Kurvapally Road	-
2		Narayanapet	Kolpur	11KV	PARAMONDODDI	15.00	17.43	02.43		Jumper cut and fallen on cross arm at mudumal (VI)	-
1	NLG	Chada	Nancharipet	11KV	Bhongir	07.05	10.00	02.55	EL	11 kv Line snapped	-
1	MDK	Sadasivapet	TSM	11KV	Sangareddy	12.08	13.17	01.09		B/D due to Jumper cut	-
1	SDPT	Gandipally	Gandipally Rural	11KV	SDPT	08.20	08.50	00.30		Jumper fault	-
2		Gandipally	Ramavaram	11KV	SDPT	09.35	10.50	01.15		Insulator failed	-
1	RR N	Somashila	Ramalayam	11KV	Kukatpally	16.15	17.15	01.00	EL	11kv line AB Cable End kit failed Near Vishal Tower Back Side at Baghameer	-
1	HYD N	Nehru Nagar	West Marredpally	11KV	C-VI	07.15	08.50	01.35	AR Tripped	No Visible Fault	