

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988									
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	2	0	2	0	2	0	0	
	Grand Total	1082	6468	0	6	0	6	0	6	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 24.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	THUKKAPUR	INDUSTRIAL	11KV	Gajwel	03.50	07.10	03.20		CONDUCTOR BURNT	-
2		Mirdoddy	Mirdoddy	11KV	Gajwel	10.40	15.50	05.10		B/D 11 Kv wire cut Lc.no.23430	-
1	RR N	Pudur	Munirabad	11KV	Medchal	07.15	09.05	01.50	BD	11KV Line Cut & Replaced at Munirabad Village	-
1	HYD N	New Bowenpally	Raju Colony	11KV	Bowenpally	09.14	10.20	01.06	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Samrat fdr
2		New Bowenpally	Shobana Colony	11KV	Bowenpally	09.15	10.18	01.03	EL,OL-Rph	Cable fault	Arranged B/F on 11KV Ferozguda fdr
3		Nehru Nagar	Rezimental Bazar	11KV	Sec-Bad	09.45	11.20	01.35	OL-R&Yph	HT Line snapped at Govt. School	-