

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988									
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	2	0	2	0	2	0	0	
	Grand Total	1082	6468	0	5	0	5	0	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 26.01.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
NIL												

TSSPDCL - LMRC / Corporate office

Date: 26.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	Laxmidevipally	Laxmidevipally	11KV	Siddipet	16:10	19:10	3:00		Conductor snapped	No
2		Potharam	Nagaram	11KV	Husnabad	13.00	13.35	00.35		DTR Problem	No
1	RR N	Aliabad	HBL	11KV	Medchal	13:45	15:25	1:40		Tree fallen on the 11KV line at Hanuman Temple, Ratnalayam	No
1	HYD C	Durga Nagar	Krishna Nagar	11KV	II	14.28	17.21	02.53	EL	33KV Lines touching to 11KV Lines	Arranged B/F on 11KV Zinda Tilismath fdr
2		Golnaka	Kamala Nagar	11KV	II	15.38	17.11	01.33	EL	Faulty loads of 11KV Krishna Nagar feeder	No