

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	0	9	0	9	0	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
NIL												

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 27.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Manthangoud	Kathwar	11kv	Narayanapet	06.30	08.52	02.22		Due to squarrel Fallen on 11KV Line	-
1	NLG	Kodur	Kodur	11kv	Suryapet	04.30	07.00	02.30	E/L	Insulator failed	-
2		Munagala	Barakathgudem	11kv	Huzurnagar	10.00	12.15	02.15	EL	11 KV LINE SNAPPED	-
3		Suddala	Thereyala	11kv	Bhongiri	14.50	16.00	01.10	EL/OL	SS-8 11KV Insulator Failed	-
1	SDPT	Rudraram	Mallupallu	11kv	Siddipet	18.40	20.30	02.50		BD Insulater failure	-
2		Komuravelli	Peddarajipeta	11kv	Husnabad	10.57	14.20	03.23		jumper cut	-
1	HYD N	Monda Market	Dharam Kanta	11kv	V	17.36	19.20	01.44	EL	Conductor snapped at Asian Wines	-----
1	HYD C	Z.P.Office	Seven Temples	11kv	I	15.57	17.10	01.13	EL,OL	Tree fallen on lines at Kilal Complex, Chinthal Basti	-----
2		Fever Hospital	C.C.Sharaf Hospital	11kv	II	18.30	19.47	01.17	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV YMCA fdr