

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	4	1	4	1	4			
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 28.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Bijinapally	33KV	Nagarkurnool	08.36	09.06	00.30	E/L&O/L	Pin Binding Replaced at Naganool (Vi)		Alternate Supply Arranged from 132KV SS Ghanapur to 33KV Lattupally & (Loads Normalized from 17:20Hrs)

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 28.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Maganoor	WADWAT	11KV	Narayanapet	07.10	08.00	00.50		Break Down due to 11kv cond snapped and cut at wadwat	-
2		Gudeballe	KOTHPALLY	11KV	Narayanapet	10.00	11.40	01.40		Break Down due to 11kv cond snapped and cut at IDC marapaa DTR	-
3		Gudeballe	SATAYASAI & LIFT	11KV	Narayanapet	15.20	16.00	00.40		Break Down due to 11kv cond snapped and cut at nalagattu	-
4		CHINNAJATRAM	CHINNAJATRAM	11KV	Narayanapet	04.35	06.30	01.55		BREAKDOWN DUE TO 11KV LINE CUT,	-
1	NLG	Bollepally	Jampally	11KV	Bhongir	12.10	14.30	02.20	EL/OL	11kv Disc Failed near Jampally (V)	-
1	SDPT	MUNIGADAPA SS	MANDAPUR	11KV	Gajwel	10.40	12.55	02.15		INSULATOR FAILED	-
2		RAIPOLE SS	CHOWDARPALLY	11KV	Gajwel	11.20	14.30	03.10		11KV LINE CUT	-
1	RR E	Balaji Nagar	Mahankali	11KV	Keesara	12.53	13.33	00.40		Tree Branches fallen on 11KV line at TVS Showroom Backside	-
1	HYD S	Santosh Nagar	Venkateswara Alayam	11KV	Asmangadh	13.53	15.44	01.51	EL,OL-Rph	Cable fault at ICICI Bank	Arranged B/F on 11KV Chndra Huts fdr