

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT			1		1		1				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	13	1	13	1	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 29.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDP	Mustyala	Nagapuri	33KV	Husnabad	17.05	18.30	01.25		Line problem	Nagapuri	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 29.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Polepally	Udandapur	11KV	Jadcherla	09.30	11.40	02.10		11KV Disk fail near Udandapur	-
2		Kothapally	Nidjinta24Hrs	11KV	Narayanapet	01.00	05.40	04.40		Break Down due to 11KV conductor snapped and cut Nidjinta Village	-
3		Nancherla	Komreddypally	11KV	Narayanapet	13.06	14.27	01.21		Break down due to 11KV Disc failed	-
4		MARIKAL	TILERU	11KV	Narayanapet	10.46	12.45	01.59		BREAKDOWN DUE TO 11KV JUMPER CUT	-
1	NLG	Repala	N S Gudem	11KV	Huzurnagar	12.15	15.00	02.45	EL	11 KV LINE SNAPPED	-
2		Pochampally	Mulkalapally	11KV	Devarakonda	08.20	08.45	00.25	EL	B/D of 11 KV Jumper Cutt	-
3		Kambalapally	Pogilla	11KV	Devarakonda	13.10	13.55	00.45	EL	B/D Of 11KV Insulator Failed	-
1	RR N	Subhash Nagar	Pragha Tools	11KV	Medchal	17.19	17.55	00.36	BD	11KV Jumper cut and replaced at Mayuri Bar	-
2		Devarayamjal	DMC	11KV	Medchal	06.40	07.30	00.50	BD	11KV Pole damaged by lorry at Birappa Temple, Yamjal	-
3		Kandlakoya	Kandlakoya	11KV	Medchal	13.50	15.20	01.30	BD	11KV Line AB Switch Opened at Cheruvukatta(No Fault) (Backfeeding arranged from 11KV IDA Kandlakoya Feeder)	-
1	RR E	AS Rao Nagar	Maruthi Nagar	11KV	Habsiguda	18.12	20.04	01.52		11Kv jumper cut at Officers Colony (LM Narsihma)	-
2		Balaji Nagar	Mahankali	11KV	Keesara	12.53	13.33	00.40		Tree Branches fallen on 11KV line at TVS Showroom Backside	-
1	HYD S	Exhibition	Seetharampet	11KV	IX	13.50	15.50	02.00	EL,OL-Rph	DTR Solid Core insulator flash over at Patel Nagar	-