

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT			1	1	1	1	1	1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	3	2	3	2	3	0	0	
	Grand Total	1082	6468	2	7	2	7	2	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 31.01.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Gummadidala	AFA	33KV	Patancheru	11.15	14.35	03.20		B/D due to Jumper cut	AFA	-
1	SDPT	Duddeda	Kondapaka	33KV	Gajwel	11.55	12.55	01.00		BD (Line problem)	Kondapaka	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 31.01.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Palem	Ogodu	11KV	Nalgonda	08.40	09.40	01.00	EL	B/D due to Insulator failed	-
1	MDK	Pati	My Home	11KV	Patancheru	12.10	14.15	02.05		B/D due to Insulator failed	-
1	SDPT	MULUGU	NARSAMPALLY	11KV	Gajwel	23.35	11.15	11.40		11KV WIRE BROKEN	-
1	RR N	Jagathgirutta	Shirdi Hills	11KV	Medchal	14.45	16.15	01.30	BD	11KV Cable endkit failed at Somaiah Nagar	-
1	RR E	Mallapur-2	Surya Nagar	11KV	Habsiguda	10.15	11.36	01.21		11KV Disc failed at Bank colony	-
1	Hyd N	Osm. University	Mettuguda	11KV	V	18.25	19.50	01.25	OL-Yph	Tree branches fallen on lines at Mettuguda	At 19:41Hrs partial fdr charged & remaining loads added on 11KV Vijaypuri fdr
1	HYD S	Khilwath	Lad Bazar	11KV	III	17.17	18.28	01.11	OL	End Kit failed at Stedment DTR (1No.DTR kept off)	-----