

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		9		9		9			
7	RR(E)	168	403		11		11		11			
8	Hyd	194	1044		8		8		8			
	Total	606	3055	0	28	0	28	0	28	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	2	17	2	17	2	17			
3	MDK	107	933		5		5		5			
4	SDPT				14		14		14			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	36	2	36	2	36	0	0	
	Grand Total	1082	6468	2	64	2	64	2	64	0	0	

TSSPDCL - LMRC / Corporate office

Date: 02.07.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Madgulapally	Seethyathanda	33KV	Miryalguda	3:50	12:10	8:20	E/L	Tree falen on the 33KV line	Seethyathanda	Laxmidevigudem at 04:30
2		Suryapet	Sudhakar PVC	33KV	Suryapet	04.20	08.10	03.50	E/L	33KV Jumper cut	Sudhakar PVC	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Indugula	Kothagudem	11KV	Nalgonda	2:55	3:26	0:31	E/L	11KV Jumper Cutt	No
2		Eduloor	Munukuntla	11KV	Nalgonda	01.00	10.00	09.00	E/L	11KV Disc Failed	No
3		Kudakuda	Kudakuda	11KV	Suryapet	04.10	07.30	03.20	E/L	11Kv Insulator failed & Tree branch fallen on the line	No
4		Balemla	Gandhi nagar Express	11KV	Suryapet	06.30	08.50	02.20	E/L	11Kv Insulator failed	No
5		Palakeedu	Nagireddy gudem	11KV	Huzurnagar	04.30	07.30	03.00	E/L	11KV Line Snapped	No
6		Mkundapuram	Somaram	11KV	Huzurnagar	07.00	08.45	01.45	E/L	11KV Disk Failed	No
7		Janpahad	Shunyapahad	11KV	Huzurnagar	07.30	08.30	01.00	E/L	11KV Jumper cut	No
8		Munagala	Barakathgudem	11KV	Huzurnagar	06.35	08.00	01.25	E/L	11KV Line Snapped	No
9		Gondiryala	Chimiryala	11KV	Huzurnagar	05.20	07.30	02.10	E/L	11KV Line Snapped	No
10		Alair	Ch.Kandukur	11KV	Bhongir	05.40	09.35	03.55	E/L	11KV Insulator Failed near Ramasamudram (V) Due to rain	No
11		Azeempet	Azeempet	11KV	Bhongir	09.00	11.50	02.50	E/L	11KV Disc Failed near Mallamagudem (V) Due to rain	No
12		Datherpally	Mallapuram	11KV	Bhongir	22.30	06.10	08.40	E/L	HT/LT Near madava reddy well , mallapuram (V)	No
13		Motakondur	Vartoor Agl	11KV	Bhongir	05.50	08.10	02.30	E/L	HT/LT near Vartoor (V)	No
14		Suddala	Bramahanapally	11KV	Bhongir	00.30	09.30	09.00	E/L	HT/LT & Tree branches fallen at line Pochamma temple near Suddala (V)	No
15		Jublakpally	Jublakpally	11KV	Choutuppal	01.37	07.26	05.49	E/L	11KV Insulator failed at Kotha. Suresh reddy well near Jublakpally (V)	No
16		Choutuppal	Chinnakondur	11KV	Choutuppal	04.00	09.30	05.30	E/L	Snake fallen at DTR	No
17		Chada	Katepally	11KV	Bhongir	1:40	7:40	6:00	E/L	Snake fallen at line near Katepally (V)	No
1	MDK	EPIP-I	Chaitanya	11KV	Sangareddy	9:55	11:47	1:52		Conductor snapped	No
2		Anrich Bollaram	Town-II	11KV	Patancheru	02.10	08.46	06.36		Insulator failure	No
3		Bollaram-II	Kottam	11KV	Patancheru	05.30	08.15	02.45		Jumper cut	No
4		Pati	My Home	11KV	Patancheru	01.30	04.02	02.32		Disc failure	No
5		Patancheru Town	Town	11KV	Patancheru	1:20	3:20	2:00		Tree branches fallen on the line	No
1		Mustabad X-Road	Raghavendranagar	11KV	Siddipet	2:05	3:35	1:30		B/D-Tree cutting-now rectified	No
2		Dubbak	Lachapet	11KV	Siddipet	06.00	09.27	03.27		11KV Disk failed	No
3		Chellapur	Chellapur	11KV	Siddipet	01.00	11.41	10.41		11KV wire cut-Now rectified.	No
4		Ramakkapet	Ramakkapet	11KV	Siddipet	00.00	10.16	10.16		Disc failed	No
5		Mirdoddi	Kasulabad	11KV	Siddipet	07.45	15.00	07.15		Disc failed	No