

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	5	1	5	1	5			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044		3		3		3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>14</b>	<b>1</b>	<b>14</b>	<b>1</b>	<b>14</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		6		6		6			
2	NLG	144	988	1	13	1	13	1	13			
3	MDK	107	933		3		3		3			
4	SDPT			2	13	2	13	2	13			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>3</b>	<b>35</b>	<b>3</b>	<b>35</b>	<b>3</b>	<b>35</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>4</b>	<b>49</b>	<b>4</b>	<b>49</b>	<b>4</b>	<b>49</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

## Circle-wise 33KV Breakdowns

Date: 08.07.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Miryalaguda	Reddys Lab	33KV	Miryalaguda	21.00	10.00	13.00	EL	Diska Failed Conductor Failed	Reddyslab	-
1	SDP	Siddipet	Rangadampally	33KV	Siddipet	00.00	03.10	03.10		B/D Disk fail	Rangadampally	-
2		Habsipur	Dubbak	33KV	Siddipet	00.15	03.40	03.25		B/D Tree branch fall on the line	Dubbak	-
1	RR N	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	09.55	11.30	01.35		33KV Line AB Switch Opened at Pokarna(Internal Problem in Pokarna)		-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 08.07.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Polkampally	11KV	Jadcherla	09.00	11.45	02.45		11KV Insulator Fail Near Polkampally (V)	-
2		Kodgal	Kodgal Agl	11KV	Jadcherla	01.03	03.08	02.05		11KV Phase To Phase Near Kodgal (V)	-
3		Donoor	Stone Crusher	11KV	Jadcherla	10.45	14.30	03.45		Cable Shot At Crusher Company Side	-
4		Makthal	Sangambanda	11KV	Narayanpet	01.47	07.40	05.53		11KV line cut at Sangambanda Agl	-
5		Paspula	Pasupula Bheema Lift	11KV	Narayanpet	03.40	07.24	03.44		Due to Rain	-
6		Paspula	Satyaram	11KV	Narayanpet	03.40	10.00	06.20		LT line Problem at panchadevpaadu(V)	-
1	NLG	Pamanagundla	Yerrasanigudem	11KV	Nalgonda	03.08	06.45	03.37	EL	11 KV AB Switch Open at A.P.Lingotam Side	-
2		Palem	Ogodu	11KV	Nalgonda	01.20	11.00	09.40	EL	11 KV Jumper Cut	-
3		Palem	Palem	11KV	Nalgonda	01.20	11.40	10.20	EL	11 KV Jumper Cut	-
4		Narsingbatla	Gadibaigudem	11KV	Nalgonda	01.00	06.45	05.45	EL	11 KV Jumper Cut	-
5		Pulicherla	Pulicherla	11KV	Miryalaguda	01.00	04.10	03.10	EL	Conduct Snnaped	-
6		Padamatipally	Yarragunta Pally	11KV	Devarakonda	04.00	06.10	02.10	EL	11 KV Jumper Cut	-
7		Bopparam	Settigudem	11KV	Suryapet	02.10	07.15	05.05	E/L	Insulator flashover	-
8		N.Annaram	Lingala	11KV	Suryapet	03.25	08.20	04.55	E/L	Insulator flashover	-
9		Thungathurthy	Ganugubanda	11KV	Suryapet	04.10	09.30	05.20	E/L	Jumper cut	-
10		Alingapuram	Gundlapally	11KV	Huzurnagar	05.00	07.30	02.30	EL	11 KV LINE SNAPPED	-
11		Dondapahad	Dondapahad	11KV	Huzurnagar	04.00	07.30	03.30	EL	11 KV JUMPER CUT	-
12		Akupamula	K K Gudem	11KV	Huzurnagar	03.00	06.40	03.40	EL	11 KV LINE SNAPPED	-
13		Peddaravulapally	Indriyala	11KV	Choutuppal	02.11	10.29	08.18	EL/OL	11 kv Line snapped near Indriyala village.	-
1	MDK	Sadasivpet	Kambalapally	11KV	Sangareddy	11.20	12.40	01.20		BD due to Tree branches fallen on line	-
2		Cheryal	Kalivemla	11KV	Sangareddy	06.05	09.50	03.45		BD due to lightning arrester failure	-
3		Inole	Pedda Kanjarla	11KV	Patancheru	04.01	05.59	01.58		BD due to Insulator failed	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDP	Thonal	Thonal	11KV	Siddipet	03.45	07.20	03.35		B/D Due to Bird fallen on line	-
2		Dubbak IPDS	Chervapur	11KV	Siddipet	10.11	10.35	00.24		B/D AB Switch problem	-
3		Gowraram	Gowraram	11KV	Gajwel	22.30	09.20	10.50		BD Due to Line cut	-
4		Wargal	Wargal	11KV	Gajwel	00.00	01.45	01.45		BD due to Disk failed	-
5		Thunkibollaram	Narsapur	11KV	Gajwel	11.50	12.20	00.30		BD due to Disk failed	-
6		Mulugu	Mulugu	11KV	Gajwel	22.08	06.00	07.52		BD due to Disk failed	-
7		Marpadaga	Marpadaga	11KV	Gajwel	02.00	08.20	06.20		Tree branches fallen on line	-
8		Bandaram	Darga	11KV	Gajwel	23.15	07.50	08.35		BD due to Disk failed	-
9		Raipole	Industrial	11KV	Gajwel	01.05	05.16	04.11		BD Due to Insulator failed	-
10		Gouravelli	Gubbadi	11KV	Husnabad	06.00	10.00	04.00		BD Due to Line cut	-
11		Ramchandrapur	Vinjalpally	11KV	Husnabad	00.00	03.05	03.05		BD Due to Line cut	-
12		Gagillapur	Vallampatla	11KV	Husnabad	00.00	00.44	00.44		Heavy gale and wind	-
13		Bekkal	Kutigal	11KV	Husnabad	00.40	11.40	11.00		Heavy gale and wind	-
1	RR N	Prashanthi Hills	Prashanthi Hills	11KV	Kukatpally	11.26	12.30	01.04		11kv Disk Failure At Seven Hills Apt	-
2		HMT	Ganesh Nagar	11KV	Medchal	01.20	02.05	00.45		No fault	-
3		Thurkapally	Yadaram	11KV	Medchal	00.00	07.21	07.21		11KV Conductor snapped at Forest Area(1 No DTR in off)	-
4		Sampanbole	Alphamed	11KV	Medchal	07.40	10.43	03.03		Bird fallen on the 11KV Line at Granite Company	-
5		Shameerpet	Devarayamjal	11KV	Medchal	07.45	11.05	03.20		11KV Disc failed at Jadhv Thota, Thumkunta Village	-
1	RR E	Moula-Ali	HCL	11KV	Sainikpuri	22.30	01.30	03.00		11Kv AB Switch Disk failed at Krishna Nagar Road No.5 (Artisan Narsihma Reddy/Sai Prakash)	-
2		Cherlapally-II	Phase-IV	11KV	Sainikpuri	22.25	02.45	04.20		11Kv 2 Polimer Disk failed at Phase-V (AE/OP)	-
3		Kushaiguda	Sai Baba Temple	11KV	Sainikpuri	10.25	11.25	01.00		11KV Jumper cut at ECIL X Road (AE)	-
4		Chakripuram	Ayyappa nagar	11KV	Keesara	01.00	02.00	01.00		11KV line cut at Shashank enclave	-
5		Chakripuram	Simhapuri	11KV	Keesara	01.00	02.10	01.10		11KV line cut at Dubbaiah appt	-
6		Chakripuram	Shilpa nagar	11KV	Keesara	06.30	07.45	01.15		Tree fallen on 11kv line at Ammaiah colony	-
1	HYD C	Industrial Area	V.S.T (Dedicated feeder)	11KV	II	01.35	14.25	12.50	EL,OL-R&Bph	CT PT fault of HT Service	-
2		Industrial Area	Mother Dairy	11KV	II	07.05	08.10	01.05	EL,OL-Rph	HT Jumper cut at Church Gally (6No. DTR's kept off)	-
3		Narayanguda	Chikkadpally	11KV	II	12.15	13.30	01.15	A/R Tripped	Jumper cut at Opp: Chandana Brothers	-