

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	1	1	1	1	1			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	1	3	1	3	1	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		2		2		2			
3	MDK	107	933	3	1	3	1	3	1			
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	7	4	7	4	7	0	0	
	Grand Total	1082	6468	5	10	5	10	5	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 09.07.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	G R Cable	33KV	Jadcherla	15.01	17.30	02.29		Due to LV's Pull Out & 33KV G R Cable Feeder Beraker Problem	G R Cable	Alternate Supply Arranged 33KV Rajapur Feeder at 17:30Hrs
1	MDK	Zaheerabad	New Allana	33KV	Zaheerabad	15:20	17:20	2:00		Jumper cut	New Allana	No
2		Borpatla	Chandapur	33KV	Jogipet	19.14	20.05	00.51		Jumper cut	Chandapur	No
3		Sadasivpet	Manjeera	33KV	Sangareddy	15.30	17.30	02.00		Due to tree branch fallen on the line	Manjeera	No
1	RR N	132KV LGM Pet	Aliabad	33KV	Medchal	14:55	16:13	1:18		33KV Outgoing Y Phase Jumper Cut & Replaced in Aliabad SS	Aliabad	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Bijwar	MAQDUMPUR	11KV	Narayanpet	08.00	09.00	01.00		Due to 11kV Insulator Failed at maqdumpur village	No
1	NLG	Bondugula	Parupally	11KV	Bhongir	15:10	16:35	1:25	EL	11kv Disc Failed near Parupally Village	No
2		Golnepally	Nemalikaluva	11KV	Choutuppal	07.23	09.02	01.39	EL	100 kva DTR failed at Maddela. Hanumanth well near Jalukaluva village	No
1	MDK	Bollaram - I	Kythan	11KV	Patancheru	7:10	8:50	1:40		Jumper cut	No
1	SDPT	WARGAL	TOWN	11KV	Gajwel	10:20	11:50	1:30		Tree branch fallen on the 11KV line	No
2		Bekkal	Kondapur	11KV	Husnabad	07.15	12.05	04.50		Insulator failed	No
3		Pandilla	Pandilla Rural	11KV	Husnabad	08.30	13.30	05.00		Insulator failed	No
1	RR N	Thumkunta	Thumkunta	11KV	Medchal	18:50	19:40	0:50	BD	Line AB Switch opened at Sports School (11KV Conductor Snapped)	No
1	HYD N	Bhudevi Nagar	Yadamma Nagar	11KV	C-VI	14.35	15.50	01.15	EL,OL	Rph female contact fault at SS	No
1	HYD C	Industrial Area	Azamabad Key SS OH	11KV	II	09.19	10.29	01.10	EL	Cable fault at Sandhya Theater	No