

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	3	8	3	8	3	8			
7	RR(E)	168	403		7		7		7			
8	Hyd	194	1044		14		14		14			
	Total	606	3055	3	29	3	29	3	29	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	4	1	4	1	4			
2	NLG	144	988	1	22	1	22	1	22			
3	MDK	107	933	1	5	1	5	1	5			
4	SDPT			1	3	1	3	1	3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	34	4	34	4	34	0	0	
	Grand Total	1082	6468	7	63	7	63	7	63	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 14.07.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanpet	19.35	22.50	03.15	E/L&O/L	Line Phase to Phase Near Lingalched(V)	Vepoor	-
1	NLG	Suryapet	Mission Bhageerada	33KV	Suryapet	02.40	07.10	04.30	EL	Jumper Cut	Mission Bhageerada	-
1	MDK	Narayankhed	Wasar	33KV	Jogipet	10.13	12.28	02.15		BD due to Tree branches fallen on line	Wasar	-
1	SDPT	Mustyala	NAGAPURI	33KV	Husnabad	07.25	09.10	01.45		B/D due to tree fallen at MPDO, Cherial	NAGAPURI	
1	RR N	132KV LGM Pet	33KV ICICI	33KV	Medchal	16.30	18.37	02.07		33KV Disc failed in 33/11KV ICICI SS	33KV ICICI	-
2		132KV Medchal	33KV Aliabad	33KV	Medchal	00.06	05.58	05.52		33KV Line AB Switch Opened at Thurkapally	33KV Aliabad	-
3		132KV Medchal	33KV Keshavaram	33KV	Medchal	11.36	15.55	04.19		No fault	33KV Keshavaram	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 14.07.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Balanagar	Mothiganapur	11KV	Jadcherla	01.10	06.00	04.50		11KV jumper Cut Near Mothiganapur (V)	-
2		Nidugurthy	Thipparaspally	11KV	Narayanpet	10.20	11.10	00.50		11KV Line cut at Thipparaspally (V)	-
3		Nidugurthy	Thipparaspally	11KV	Narayanpet	12.30	13.10	00.40		LT line cut at Thipparaspally (V)	-
4		Mustipally	Anugonda	11KV	Narayanpet	04.00	07.46	03.46		11KV line cut at Anugonda (V)	-
1	NLG	Pamanagundla	Ismailpally	11KV	Nalgonda	14.46	16.32	01.46	EL	11KV Jumper cut	-
2		Nakrekal	Nomula	11KV	Nalgonda	14.05	16.58	02.53	EL	11KV Jumper cut	-
3		Koppole	Bheemaram	11KV	Nalgonda	12.15	17.40	05.25	EL	HT/LT phase to phase	-
4		Kattangur	Bollepally	11KV	Nalgonda	03.40	08.30	04.50	EL	Tree Branch Fallen on 11KV Line	-
5		Aitipamula	Gangadevigudem	11KV	Nalgonda	06.10	11.30	05.20	EL	Tree Branch Fallen on 11KV Line	-
6		Yacharam	Marepally	11KV	Miryalaguda	00.00	06.35	06.35	EL	11KV Conductor Snapped Near Village	-
7		Pulicherla	Pulicherla	11KV	Miryalaguda	00.00	06.00	06.00	EL	Tree Branch Fallen on 11KV Line	-
8		Seethya Thanda	Thopucherla	11KV	Miryalaguda	09.27	13.24	03.57	EL	11KV PIN INSULATOR FAILED	-
9		Velmagudam	Peddagudem	11KV	Miryalaguda	08.10	11.30	03.20	EL	11KV conductor snapped near village	-
10		Seetipalem	Vemulapally AGL	11KV	Miryalaguda	00.10	06.25	06.15	EL	11KV TREE BRANCHES FALLEN ON LINE	-
11		Kothapally	Pervalala	11KV	Devarakonda	13.30	16.10	02.40	EL	Conductor Snapped	-
12		Kopple	Bollaram	11KV	Devarakonda	06.40	10.00	03.20	EL	Pin insulator Failed	-
13		Teldevarapally	Ganpur	11KV	Devarakonda	07.10	10.25	03.15	EL	Pin insulator Failed	-
14		Palvai	Kalwapally	11KV	Devarakonda	08.00	09.25	01.25	EL	Conductor Snapped	-
15		Nampally	Peddapuram	11KV	Devarakonda	06.00	08.45	02.45	EL	Pin insulator Failed	-
16		T.Giri	N.B Thanda	11KV	Suryapet	02.10	07.25	05.15	E/L	Conductor snapped	-
17		Reddygudem	Kukkadam	11KV	Suryapet	02.30	06.35	04.05	E/L	Jumper cut	-
18		Indl. Estate	Vijayacolony	11KV	Suryapet	00.00	02.10	02.10	E/L	Conductor snapped	-
19		Mukundapuram	Somaram	11KV	Huzurnagar	06.05	08.00	01.55	EL	11 KV LINE SNAPPED	-
20		Aligapuram	Chennaipalem	11KV	Huzurnagar	04.00	06.30	02.30	EL	11 KV LINE SNAPPED	-
21		Mothkur	Kondagadapa	11KV	Bhongiri	05.30	07.35	02.05	EL/OL	11 kv Insulator failed near Patimatla village	-
22		Suddala	Pallepahad	11KV	Bhongiri	02.35	08.20	05.45	EL/OL	11 kv Insulator failed at Suddala madava reddy well	-
1	MDK	SOL	Markwell	11KV	Patancheru	19.15	20.30	01.15		BD due to Insulator failed	-
2		Patancheru Town	MIA-I	11KV	Patancheru	01.20	04.50	03.30		BD due to Tree branches fallen on line	-
3		Patancheru Town	High power	11KV	Patancheru	02.40	04.30	01.50		BD due to Tree branches fallen on line	-
4		Bollaram - I	Sulaxshana-I	11KV	Patancheru	06.10	10.40	04.30		BD due to Conductor snapped	-
5	Bollaram - II	Kottam	11KV	Patancheru	18.24	20.53	02.29		BD due to Insulator failed	-	
1	SDPT	Ramancha	Gangapur	11KV	Siddipet	01.00	10.40	09.40		B/D-Insulator fail-now rectified.	
2		POTHARAM	POTHARAM TOWN	11KV	Husnabad	07.10	09.05	01.55		TREE FALL	
3		Chityal	Dommeta	11KV		05.30	12.35	07.05		Tree fallen in line	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	G Vikas	Reddy Colony	11KV	Kukatpally	02.00	03.05	01.05		11kv Pin Insultor Failure At Praja Centre	-
2		Vijayanagar	Shanthinagar	11KV	Kukatpally	02.00	03.15	01.15		11kv HT Jumper Cut Touched on Channel At M L A Gandhi House	-
3		Kompally	Vensai	11KV	Medchal	01.37	03.37	02.00		11KV Line AB Switch Opened at KVR Garden(2 No DTR's in off)11KV AB Cable Kit Failed	-
4		Petbasheerabad	Satyam Enclave	11KV	Medchal	00.05	01.05	01.00		Tree Fallen on 11KV Line at Dandamudi backside	-
5		Aliabad	Bommarajpet	11KV	Medchal	15.25	16.25	01.00		11KV Disc failed at LGM Pet Opposite Venture	-
6		Nuthankal	Lingapur	11KV	Medchal	07.35	08.25	00.50		Tree Fallen on 11KV Line at Lingapur Road	-
7		GP Pally	GP Pally	11KV	Medchal	18.50	19.45	00.55		Tree fallen on the 11KV Line at GP Pally	-
8		Kistapur	IDA Hanuman	11KV	Medchal	00.00	05.20	05.20		11KV Conductor Snapped and replaced at Gurukula Hostal	-
1	RR E	IDA Uppal	Jersey	11KV	Habsiguda	18.58	20.50	01.52		11KV Pin Insulator failed at Aishu Package company at IDA Uppal	-
2		IDA Uppal	Srikrishna	11KV	Habsiguda	19.30	21.45	02.15		AB Cable failed at Shivanethra company DTR at IDA Uppal	-
3		Uppal Kalsa	Shanthi Nagar	11KV	Habsiguda	20.44	22.05	01.21		Tree Branches fallen on 11kv Line	-
4		Moula ali	Gayatri Nagar	11KV	Sainikpuri	18.14	19.14	01.00		11KV Pin Insulator failed at Happy Home	-
5		Janapriya	High Tension	11KV	Sainikpuri	18.22	19.30	01.08		11KV Disk failed at Deccan Grammen Bank at Kapara Road (Artisian Panthulu)	-
6		Moula ali	Kailasagiri	11KV	Sainikpuri	20.23	01.15	04.52		Lorry dashed to inter linking line at Venkateswara Nagar	-
7		Moula ali	Venkateswara Nagar	11KV	Sainikpuri	20.23	00.58	05.50		Lorry dashed to inter linking line at Venkateswara Nagar	-
1	HYD N	Gymkhana	Ranibagh	11KV	C-VI	21.11	23.42	02.31	EL,OL	3no's Disc Insulator flash over at Rani Bagh	
1	HYD S	Panjasha	Asra Hosptial	11KV	III	20.35	21.45	01.10	All Indication	No Visible Fault	-----
2		Ch' Baradari	Gazi Banda	11KV	III	20.55	22.45	01.50	OL-Bph	Cable fault at Kummarwadi Masjid	-----
3		Falaknuma	Vattapally	11KV	III	21.35	23.03	01.28	EL,OL	I/C Cable fault at Vattapally	Arranged B/F on 11KV Falaknuma UG feeder
4		Falaknuma	Jangammet OH	11KV	III	22.50	00.27	01.37	EL,OL	No Visible Fault (due to Rain)	-----
1	HYD C	S.D Hospital	Ahmed Nagar Cable	11KV	VII	19.25	21.25	02.00	EL,OL-Rph	AB Cable fault at Syeed Nagar	-----
2		Fever Hospital	Tourist Hotel	11KV	II	20.20	21.30	01.10	All Indication	CT/PT fault at Badhruka College	-----
3		Nampally	Yousufin Darga	11KV	VII	20.07	22.15	02.08	EL,OL-Rph	Big tree fallen on lines beside Honda Show Room	-----
4		S.D Hospital	Ahmed Nagar OH	11KV	VII	20.37	22.55	02.18	EL	Pin Insulator flash over at Bondalagadda	-----
5		Golconda	Darga Cable	11KV	VII	20.45	22.03	01.18	EL	AB Cable fault near SS	Arranged B/F on 11KV Arvind Nagar feeder
6		Nampally	Bada Masjid	11KV	VII	21.10	22.58	01.48	EL	Isolated faulty AB Cable at Hashima Residency	(1no DTR kept off)
7		Golconda	Shaikpet W.W	11KV	VII	21.40	23.40	02.00	EL,OL-Bph	DTR fault at Green Value, O.U Colony	-----
8		Vittalwadi	Gandhi Kuteer	11KV	II	21.51	01.13	03.22	EL,OL-Bph	Jumper cut, tree branches fallen on lines at Mellcourt Park, Moisture in RMU at Air Bus Apartment & AB Switch fault at SS	
9		Bathkammakunta	Ahobilmutt	11KV	II	22.58	02.46	03.48	Auto Reclouser	Disc insulator flash over at Azam House & tree branches on lines at D.D Colony	