

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988		9		9		9			
3	MDK	107	933		1		1		1			
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	21	0	21	0	21	0	0	
	Grand Total	1082	6468	0	29	0	29	0	29	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 16.07.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Polkampally	11KV	Jadcherla	00.00	06.12	06.12		11 KV Insulator fail near Polkampally	-
2		Kaverammamet	Town	11KV	Jadcherla	02.45	04.21	01.36		11 KV Insulator fail near Kaverammamet	-
3		Bijwar	Pulimamidi	11KV	Narayanpet	02.13	10.53	08.40		Breakdown due to 25kva DTR fail at edivelli vlg	-
4		Paspula	Satyaram	11KV	Narayanpet	12.04	12.20	00.16		Breakdown due to rain, supply restored by itself	-
1	NLG	Indl.Estate	Vijaya colony	11KV	Suryapet	02.15	06.00	03.45	E/L	Disk Failed	-
2		Palakeedu	Palakeedu	11KV	Huzurnagar	05.20	07.20	02.00	EL	11 KV LINE SNAPPED	-
3		Ghanpur	Polkampally	11KV	Devarakonda	06.00	11.00	05.00	EL	pin insulator failed jumper cut	-
4		Marriguda	Y.G.Pally	11KV	Devarakonda	01.15	06.50	05.35	EL	Conductor Snapped	-
5		Kattangur	Kattangur	11KV	Nalgonda	00.00	06.00	06.00	EL	Tree Branches Fallen on the Line	-
6		Palem	Ogodu	11KV	Nalgonda	02.30	07.45	05.15	EL	11KV jumper cut	-
7		Pajjur	Pajjur	11KV	Nalgonda	12.35	14.05	01.30	EL	11KV jumper cut	-
8		B.Ramaram	Hajipur	11KV	Bhongir	12.20	13.00	00.40	EL	Solid core insulator failed at madava reddy25 kva Dtr near Dharmareedy gudem	-
9		Sharajipet	Kolluru	11KV	Bhongir	08.10	09.05	00.55	EL	100 kva DTR failed at SS-1 Near Kolluru village	-
1	MDK	Patancheru Town	Town Indl.	11KV	MIA-I	13.35	16.45	03.10		BD due to Conductor snapped	-
1	SDP	Raghavapur	Peddalingareddypally	11KV	Siddipet	03.40	16.00	12.20		B/D 11 Kv Disc Fail	-
2		Pregnapur	Gudanapally Agl	11KV	Gajwel	12.45	14.22	01.37		Disc Failed	-
3		Pamulaparthi	Pathur	11KV	Gajwel	10.30	12.30	02.00		11Kv Line Cut	-
4		Mulugu	Nagireddypally	11KV	Gajwel	13.20	14.45	01.25		Insulator Failed	-
5		Nemtur	Jabbapur	11KV	Gajwel	12.16	15.30	03.14		Disc Failed	-
6		Gagillapur	Narsaipally	11KV	Husnabad	17.49	18.42	00.53		Line cut	-
7		Chityal	Thadoor	11KV	Husnabad	13.50	14.25	00.35		Jumper cut	-
1	RR N	Subash Nagar	Meenakshi	11KV	Medchal	05.25	05.50	00.25	BD	11KV Line AB Switch Opened at Metro Backside(Disc failed)	-
2		HMT	Manikya Nagar	11KV	Medchal	18.20	19.00	00.40	BD	Bird fallen on the 11KV Line at Kakatiya Nagar	-
1	RR E	Anand Bagh	Kalyan Nagar	11KV	Sainikpuri	00.40	01.38	00.58		Tree fallen on 11Kv line at near Kamal Priya Roop Garden (AE/OP)	-
2		Keesara	Bogaram	11KV	Keesara	11.42	12.37	00.55		11KV Jumper cut at Keesara Padala T/F	-
1	HYD C	Golnaka	Nehru Nagar	11KV	II	08.37	09.44	01.07	EL,OL	HG fuse blown at Goods School	-----
2		Bathkamma Kunta	Ahobilmutt	11KV	II	10.01	12.17	02.16	EL	No Visible Fault	Arranged partial loads B/F on 11KV Saibaba Temple fdr
3		Gudimalkapur	Sharada Nagar	11KV	VII	10.52	11.55	01.03	OL-R&Bph	Pin Insulator flash over at Pillar No.57	-----
4		Vittalwadi	APCO	11KV	II	19.50	21.05	01.15	EL	Faulty 3Nos.DTRs at Anjaiah Nagar	Arranged B/F on 11KV Preventive Medicine fdr