

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		9		9		9			
	Total	606	3055	0	10	0	10	0	10	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	6	1	6	1	6			
2	NLG	144	988		3		3		3			
3	MDK	107	933	2	6	2	6	2	6			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	15	3	15	3	15	0	0	
	Grand Total	1082	6468	3	25	3	25	3	25	0	0	

TSSPDCL - LMRC / Corporate office

Date: 17.07.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Chinnamaroor	Velgonda	33KV	Wanaparthi	04.20	09.40	05.20	E/L	Due to Rain, No Visible Fault Supply stood OK	Velgonda	No
1	MDK	Zaheerabab	Mannapur	33KV	Zaheerabab	10:05	13:40	3:35		Tree branch fallen on the line	Mannapur	No
2		Zaheerabab	Old Allana	33KV	Zaheerabab	11.20	13.10	01.50		Tree branch fallen on the line	Old Allana	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nidugurthy	LAXMIPALLY	11KV	Narayanpet	06.15	08.30	02.15		DTR failed at laxmipally vlg	No
2		Jaklair	BONDALKUNTA	11KV	Narayanpet	00.10	09.45	09.35		Due to heavy rain and 11kv jumper touched to cross arm at bondalkunta vlg	No
3		Mustipally	ANUGONDA	11KV	Narayanpet	02.00	07.00	05.00		Due to heavy rain and insulator fail and disc fail at anugonda agl	No
4		Maganoor	MAGANOOR	11KV	Narayanpet	2:04	8:54	6:50		Due to heavy rain and 11kv insulator fail at maganoor town	No
5		Maganoor	ADIVISATYARAM	11KV	Narayanpet	6:00	11:30	5:30		Due to 11kv disc failed at adivisatyaram vlg	No
6		Manthangode	KATROPALLY	11KV	Narayanpet	05.30	10.05	04.35		Due to 11kv insulator fail at ernaganpally vlg	No
1	NLG	Palakeedu	Nagireddy Gudem	11KV	Huzurnagar	6:00	7:45	1:45	EL	11 KV Line Snapped	No
2		Bollepally	Jampally	11KV	Bhongiri	10.45	11.40	00.55	EL/OL	11kv Line Snapped near Venkat reddy well Jampally Village	No
3		Champur	Champur	11KV	Bhongiri	00.20	10.00	09.40	EL/OL	11KV Insulator Failed Near Reghulakunta Village	No
1	SDPT	Wardarajpur	Shivar Venkatapur	11KV	Gajwel	15:46	16:29	0:43		11KV line cut	No
2		Gowraram	Pamulaparthi	11KV	Gajwel	8:10	10:20	2:10		HT/LT line work	No
3		Dommata	Gajulapally	11KV	Gajwel	11:10	14:20	3:10		Disc failed	No
4		Dommata	Dommata	11KV	Gajwel	18:14	19:30	1:16		Disc failed	No
5		Chityala	Dommata	11KV	Husnabad	0:00	7:40	7:40		Due to heavy rain	No
6		Chityala	Dommata	11KV	Husnabad	8:15	10:15	2:00		Tree cutting	No
1	RR E	Keesara	Vardhana	11KV	Keesara	17:31	18:21	0:50		Bird fallen on 11KV line at Kundanapally Chourastha	No
1	HYD N	Allwyn	Sanath Nagar	11KV	IV	19.44	21.40	01.56	EL	Pin Insulator flash over at Sanath Nagar	No
2		Janapriya	Shankarlal Nagar	11KV	IV	20:55	22:20	1:25	EL,OL	AB Cable sparking at Ganesh Temple	No
1	HYD S	Miralam	N.S.Kunta	11KV	III	20.35	21.45	01.10	EL	No Visible Fault	No
2		Falaknuma	Falaknuma UG	11KV	III	20:40	22:56	2:16	EL	AB Cable fault at Bibi Ka Chasma	No
1	HYD C	Asif Nagar	Padmanabha Nagar	11KV	VII	20.19	21.35	01.16	EL	No Visible Fault	No
2		Asif Nagar	Military	11KV	VII	20.28	22.15	01.47	EL	No Visible Fault	No
3		Asif Nagar	Mehdipatnam Cable	11KV	VII	20.56	22.10	01.14	EL,OL	No Visible Fault	No
4		Asif Nagar	Mehdipatnam OH	11KV	VII	20:29	22:30	2:01	EL	DTR Fault at Chennai Shopping Mall	No
5		Amberpet	Patel Nagar	11KV	II	20.51	22.33	01.42	EL,OL-Rph	Pin Insulator flash over at Azad Nagar Masjid	No