

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		6		6		6			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		8		8		8			
3	MDK	107	933		1		1		1			
4	SDPT			3	7	3	7	3	7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	17	3	17	3	17	0	0	
	Grand Total	1082	6468	3	25	3	25	3	25	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 01.06.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Siddipet	Narsapur	11KV	Siddipet	1:00	14:00	14:00		BD Heavy rain & wind		-
2		Husnabad	Katkur	11KV	Husnabad	1:00	10:00	10:00		BD Heavy rain & wind		-
3		Mustyal	Nagpuri	11KV	Husnabad	22:30	23.35	0.05		BD Heavy rain & wind		Komuravelly 33kv from 23:35

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 01.06.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Karkonda	Khanapur	11KV	Jadcherla	05.15	10.15	05.00		11KV Insulator Failed Near Biramguda	-
1	NLG	Pamanagundla	Yerrasanigudem	11KV	Nalgonda	04.00	08.00	04.00	E/L	11KV Line Jumpet	-
2		Pamanagundla	Ismailpally	11KV	Nalgonda	08.30	11.30	03.00	E/L	11KV Line Jumpet	-
3		Nuthankal	Polumalla	11KV	Suryapet	03.10	06.00	02.50	E/L	Conductor snapped	-
4		Munagala	Thadvai	11KV	Huzurnagar	00.00	07.45	07.45	EL	11 KV LINE SNAPPED	-
5		Velmagudem	11KV Basireddypally	11KV	Miryalaguda	15.55	17.20	01.25	EL	11KV conductor snapped	-
6		Addagudur	Dharmaram	11KV	Bhongir	01.00	06.40	05.40	EL/OL	16 KVA DTR failed near Dharmaram village	-
7		Shivannagudem	Venkapally	11KV	Devarakonda	13.55	16.50	02.55	EL/OL	11KV Line Jumpet	-
8		Devarakonda	Mynampally	11KV	Devarakonda	16.00	17.25	01.25	EL/OL	Conductor snapped	-
1	MDK	Sangareddy - II	Filterbed	11KV	Sangareddy	18.30	20.55	02.25		BD due to After petrolling no fault found	-
1	SDPT	Ponnala	Ponnala	11KV	Siddipet	00.00	10.10	10.10		B/D Tree brach fall on the line	-
2		Irkode	Burgupally	11KV	Siddipet	06.00	17.25	11.25		B/D Disk fail	-
3		Peddakodur	Mandapally	11KV	Siddipet	00.00	10.00	10.00		B/D Disk fail	-
4		Pamulaparthy SS	Ipplagudem	11KV	Gajwel	16.06	17.19	01.13		25KVA DTR DOWN FALLEN AND AB SWITCH OPEN	-
5		Cheelasagar SS	Agl. Feeder	11KV	Gajwel	15.00	17.00	02.00		HT /LT	-
6		Raipole SS	Chowdarpally	11KV	Gajwel	07.43	09.57	02.14		TREE BRANCH WAS FALLEN ON THE 11KV LINE	-
7		Doulthabad SS	Lingarajpally	11KV	Gajwel	09.52	10.40	00.48		TREE BRANCH WAS FALLEN ON THE 11KV LINE	-
1	RR E	Nacharam indore	Ram reddy nagar	11KV	Habsiguda	17.14	18.24	01.10		Camelian fallen on 11kv line at Shawarka nagar srinivas tower opp	-
2		RGK	Barshipeta	11KV	Sainikpuri	17.58	18.55	00.57		Tree fallen on 11Kv line at Villa Spring (LM Rajendar)	-
3		Janapriya	Janapriya	11KV	Sainikpuri	18.15	19.30	01.15		11KV Insulator failed at Janapriya (AE)	-
4		Saketh	Pranam	11KV	Sainikpuri	17.50	19.40	01.50		11KV Insulator failed at RTC Colony (AE)	-
5		NN Colony	Jai Jawan	11KV	Sainikpuri	18.36	21.30	02.54		11Kv 3 Disk failed at Jai Jawan Colony (AE)	-
6		CRPF	Chennapur	11KV	Keesara	18.10	20.15	02.05		Tree fallen on 11kv line adraspally	-
1	HYD N	Macha Bollaram	Ayyappa Nagar	11KV	C-VI	18.12	19.20	01.08	A/R Tripped	Pin Insulator flash over at M.E.S Colony	18:58Hrs partial fdr charged remaining loads added on 11KV Father Balaiah Nagar feeder

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
2		Alwal	Dharma Kanta	11KV	C-VI	23.05	00.36	01.31	EL	Post type Insulator flash over at Neeladri Apts	-----