

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	2	13	2	13	2	13			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	2	22	2	22	2	22	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	20	2	20	2	20			
2	NLG	144	988	2	39	2	39	2	39			
3	MDK	107	933	2	8	2	8	2	8			
4	SDPT			6	55	6	55	6	55			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	12	122	12	122	12	122	0	0	
	Grand Total	1082	6468	14	144	14	144	14	144	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amarchinta	Atmakur	33KV	Wanaparthi	02.20	02.30	00.10	E/L&O/L	Due to Rain	Atmakur	Alternate Supply Arranged From 33KV Amarchinta Feeder at 2:30Hrs.
2		Amarchinta	Peddakadmoor	33KV	Wanaparthi	04.00	09.50	05.50	E/L&O/L	Insulator Failed at Sub Station	Peddakadmoor	No
1	NLG	Suryapet	Nuthankal	33KV	Suryapet	7:40	10:40	3:00	EL/OL	No fault found in the field Due to Rain	Nuthankal	No
2		Suryapet	Nemmikal	33KV	Suryapet	07.40	11.35	03.55	EL/OL	No fault found in the field Due to Rain	Nemmikal	No
1	MDK	Borpatla	Chandapur	33KV	Jogipet	2:00	3:19	1:19		B/D Due to Insulator Failure	Chandapur	No
2		Sadasivpet	Manjeera	33KV	Sangareddy	07.10	08.15	01.05		BD Due to tree branch fallen on the line	Manjeera	No
1	SDPT	Shanigaram	Chelimeda	33KV	Husnabad	4:45	9:20	4:35		Insulator replaced	Chelimeda	No
2		Chandlapur	Jakkapur	33KV	Siddipet	04.52	08.06	03.14		Due to Hwvey Rain	Jakkapur	No
3		Siddipet	Thornala	33KV	Siddipet	03.45	06.20	02.35		Due to Hwvey Rain	Thornala	No
4		Siddipet	Narayanaraopet	33KV	Siddipet	03.25	12.15	08.50		Due to Hwvey Rain	Narayanaraopet	No
5		Gajwel	Ahmedipur	33KV	Gajwel	05.12	13.40	08.28		Insulator failed	Ahmedipur	No
6		Gajwel	B V pur	33KV	Gajwel	10:20	11:15	0:55		Insulator failed	B V pur	No
1	RR N	132KV Medchal	Athively	33KV	Medchal	2:50	7:30	4:40		No visible fault	Athively	No
2		132KV Medchal	Athively	33KV	Medchal	09.20	10.56	01.36		33KV Pin Insulator failed at near Athively	Athively	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mothiganpur	Medigadda thanda	11KV	Jadcherla	04.10	09.00	04.50		BD due to 11 KV jumper cut near Medigadda thanda	No
2		Kandoor	Kandoor	11KV	Jadcherla	05.45	09.15	03.30		BD due to 11 KV Disk fail near SC colony at Kandoor.	No
3		Utkoor	KOLLUR	11KV	Narayanpet	00.40	06.30	05.50		Breakdown due to LT line phase to phase at amisthapur vlg	No
4		Manthangoud	KATHWAR	11KV	Narayanpet	3:10	8:20	5:10		Breakdown due to tree touching to 11kv line at kathwar vlg	No
5		Manthangoud	KATROPALLY	11KV	Narayanpet	3:06	6:11	3:05		Breakdown due to heavy gale and wind	No
6		Lingampally	LINGAMPALLY	11KV	Narayanpet	4:00	9:00	5:00		Breakdown due to heavy gale and wind	No
7		Paspula	SATYARAM	11KV	Narayanpet	15:10	15:50	0:40		Breakdown due to squirrel fallen on 11kv line at goplapur vlg	No
8		KOSGI	SAMPALLI	11KV	Narayanpet	3:45	8:15	4:30		Breakdown due to insulator fail at malreddypally vlg	No
9		SARJAKANPET	TOGAPOOR	11KV	Narayanpet	5:30	6:30	1:00		Breakdown due to heavy gale and wind and rain	No
10		KOTHAPALLY	BOONEED	11KV	Narayanpet	6:25	7:48	1:23		Breakdown due to heavy gale and wind and rain	No
11		VENNACHEDU	JANAMPALLY	11KV	Narayanpet	4:38	7:05	2:27		Breakdown due to tree branch fallen on 11kv line at janampally vlg	No
12		PALLERLA	NADIPAD	11KV	Narayanpet	2:40	8:00	5:20		Breakdown due to tree branch fallen on 11kv line at pallerla vlg	No
13		PERAPALLA	PERAPALLA	11KV	Narayanpet	1:10	6:50	5:40		Breakdown due to insulator fail at pothula madugu vlg	No
14		APPAKPALLY	APPIREDDYPALLY	11KV	Narayanpet	3:12	6:00	2:48		Breakdown due to insulator fail at appireddypally vlg	No
15		Bijwar	MAQDUMPUR	11KV	Narayanpet	9:00	10:30	1:30		Breakdown due to 11kv disc fail at maqdumpur vlg	No
16		Bijwar	BIJWAR	11KV	Narayanpet	6:00	7:00	1:00		Breakdown due to 11kv disc fail at kothapally vlg	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
17		DAMARGIDDA	DAMARAGIDDA	11KV	Narayanpet	4:10	6:40	2:30		Breakdown due to tree branch fallen on 11kv line at damargidda vlg	No
18		DAMARGIDDA	SAJNAPUR	11KV	Narayanpet	4:15	10:15	6:00		Breakdown due to 11kv disc fail at sajnapur vlg	No
19		DAMARGIDDA	BAPANPALLY	11KV	Narayanpet	4:30	7:50	3:20		Breakdown due to insulator fail at bapanpally vlg	No
20		KYATHANPALLY	WATTUGUNDLA	11KV	Narayanpet	07.18	08.29	01.11		Breakdown due to insulator fail at kamsanpally vlg	No
1	NLG	Turkapally	Hydalapur	11KV	Nalgonda	10:08	11:10	1:02	EL	Insulator Failed	No
2		Eduloor	Munukuntla	11KV	Nalgonda	07.00	08.30	01.30	EL	Jumper Cut	No
3		Thummadam	Thummadam	11KV	Miryalaguda	06.20	09.20	03.00	EL	Disk Failed	No
4		Seetya Thanda	Thopucharla	11KV	Miryalaguda	08.10	10.30	02.20	EL	Tree Fallen on the Line	No
5		Seetya Thanda	Seetya Thanda	11KV	Miryalaguda	08.10	13.15	05.05	EL	Jumper Cut	No
6		Gurrampode	Chepuru	11KV	Devarakonda	12.17	14.10	01.53	EL	11 Kv Insulator failed	No
7		Gurrampode	Pittalagudem	11KV	Devarakonda	12.17	15.02	02.45	EL	11 Kv 2 Nos Insulator failed	No
8		Nampally	Mandhanpuram	11KV	Devarakonda	10.07	11.41	01.34	EL	11 kv Jumper Cutt	No
9		Cherukupally	Nijamnagar	11KV	Devarakonda	07.10	09.20	02.10	EL	11 Kv Insulator failed	No
10		Penpahad	Macharam	11KV	Suryapet	03.40	08.10	04.30	E/L	Poles Damaged & Conductor snapped	No
11		Thatipamula	Sri ram thanda	11KV	Suryapet	07.50	12.00	04.10	E/L	Tree branch fallen on the line	No
12		Reddygudem	Kothagudem	11KV	Suryapet	10.45	15.00	04.15	E/L	Conductor snapped	No
13		B.Chandupatia	V.K Pahad	11KV	Suryapet	13.50	15.45	01.55	E/L	Jumper cut	No
14		Dirsenapally	Lingampally	11KV	Suryapet	11.30	15.40	04.10	E/L	Conductor snapped	No
15		Yerkaram	Rajnaik thanda	11KV	Suryapet	10.30	15.05	04.35	E/L	Conductor snapped & Bird fallen	No
16		Mukundapuram	Mukundapuram	11KV	Huzurnagar	06.15	09.00	02.45	EL	Havy rain and wind	No
17		Gaddipally	Gaddipally	11KV	Huzurnagar	04.00	07.30	03.30	EL	11 KV Line snapped	No
18		Gaddipally	Ponugodu	11KV	Huzurnagar	03.00	08.45	05.45	EL	11 KV Insulator Failed	No
19		Repala	Repala	11KV	Huzurnagar	00.00	08.30	08.30	EL	Havy rain and wind	No
20		Repala	Kalakova	11KV	Huzurnagar	04.00	09.30	05.30	EL	11 KV Jumper cut	No
21		Repala	V R puram	11KV	Huzurnagar	06.00	09.45	03.45	EL	11 KV Line snapped	No
22		Munagala	Turkagudem-1	11KV	Huzurnagar	20.40	08.45	12.05	EL	11 KV Line snapped	No
23		Timmareddy gudem	Timmareddy gudem	11KV	Huzurnagar	03.00	07.45	04.45	EL	11 KV Tree falleon	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
24		Ananthagiri	Mogalaikota	11KV	Huzurnagar	04.30	08.40	04.10	EL	11 KV Line snapped	No	
25		Nandanam	Thukkapur	11KV	Bhongir	04.40	11.20	06.40	EL/OL	11 KV Disc failed near Jittolabavi	No	
26		Bollepally	Sureypally	11KV	Bhongir	09.20	11.10	01.50	EL/OL	11kv Disc Failed near Sureypally Village	No	
27		Bollepally	Jampally	11KV	Bhongir	09.50	13.00	03.10	EL/OL	11kv Insulator Failed near Jampally Village	No	
28		Chandupatla	Indl	11KV	Bhongir	06.30	11.15	04.45	EL/OL	11 kv Insulator failed near Kunoor village	No	
29		Venkiryala	Venkiryala	11KV	Bhongir	06.36	11.30	04.54	EL/OL	11 kv insulator failed near Venkiryala village.	No	
30		Pamukunta	Jala	11KV	Bhongir	06.30	07.30	01.00	EL/OL	11 kv Disc failed near Jala village	No	
31		Bondugula	Bondugula Agl	11KV	Bhongir	06.30	12.20	05.50	EL/OL	11kv Line Snapped near Bondugula Village	No	
32		Addagudur	Indl	11KV	Bhongir	14.46	15.55	01.09	EL/OL	15kva DTR Failed Addagudur Village	No	
33		Ambala	Modugubavigudem	11KV	Bhongir	09.25	14.05	04.40	EL/OL	11kv Insulator Failed near Modhugubavi gudem Village	No	
34		Choutuppal	Chinnakondur	11KV	Choutuppal	11.00	14.20	03.20	EL/OL	11KV Insulator Failed near Chinnakondur Village	No	
35		Malkapur	Vijay polymer	11KV	Choutuppal	06.00	12.18	06.18	EL/OL	11kv Insulator Failed near Sub station	No	
36		S.Lingotam	Lingo jigudem Agl	11KV	Choutuppal	09.03	13.15	04.12	EL/OL	11KV Insulator Failed near Panthnagi Road	No	
37		Narayanapur	Gudimalkapur	11KV	Choutuppal	10.20	12.40	02.20	EL/OL	11kv Insulator Failed near Gudimalkapur Village	No	
38		BP.Pally	Bheemanapally	11KV	Choutuppal	05.45	11.40	05.55	EL/OL	11 kv Insulator failed near Bheemanapally village.	No	
39		Jublakpally	Indl	11KV	Choutuppal	5:04	9:35	4:31	EL/OL	11 kv Disc failed at Poultry farm near Jublakpally village	No	
1		MDK	Isnapur	Patodia	11KV	Sangareddy	7:10	8:10	1:00		B/D Due to Conductor Snapped	No
2			Isnapur	IDA Isnapur	11KV	Sangareddy	07.10	08.10	01.00		B/D Due to Conductor Snapped	No
3			EPIP-II	Srinivasa Costing	11KV	Sangareddy	05.30	06.35	01.05		B/D Due to Conductor Snapped	No
4	Inole		Sathyasai WW	11KV	Sangareddy	03.45	07.40	03.55		B/D Due to Insulator Failure	No	
5	Patancheru Town		Town	11KV	Patancheru	06.30	07.25	00.55		B/D Due to Insulator Failure	No	
6	Patancheru Town		Town	11KV	Patancheru	16.40	17.25	00.45		B/D Due to Insulator Failure	No	
7	Bollaram - II		Rupa	11KV	Patancheru	03.30	09.30	06.00		B/D Due to tree Branch fallen on the line	No	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
8		Bollaram - II	Vipla	11KV	Patancheru	19:33	21:00	1:27		B/D Due to Jumper Cut	No
1		Potharam	Nagaram	11KV	Husnabad	8:15	8:30	0:15		Line Problem	No
2		Thotapally	Veerapur	11KV	Husnabad	06.10	11.30	05.20		HT/LT line	No
3		Hunsabad	Pandilla	11KV	Husnabad	09.25	11.25	02.00		Line Problem	No
4		Gouravelli	Gouravelli	11KV	Husnabad	04.50	08.00	03.10		Line Problem	No
5		Chityala	Dhommata	11KV	Husnabad	04.50	14.45	09.55		Disk Fail	No
6		Komuravelli	Posanpally	11KV	Husnabad	04.05	09.40	05.35		Line cut	No
7			Komuravelli Agl	11KV	Husnabad	04.30	09.40	05.10		3-Ph Break down	No
8		Guruvannapet	Guruvannapet	11KV	Husnabad	05.00	12.00	07.00		Line problem	No
9			Posanpally	11KV	Husnabad	06.00	12.00	06.00		Line problem	No
10		Narsapur	Narsapur	11KV	Siddipet	03.02	10.16	07.14		B/D	No