

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		12		12		12			
2	NLG	144	988		7		7		7			
3	MDK	107	933		1		1		1			
4	SDPT				15		15		15			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	35	0	35	0	35	0	0	
	Grand Total	1082	6468	0	40	0	40	0	40	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 05.06.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1									Nil			

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 05.06.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Ponnakal	Rachala	11KV	Jadcherla	05.10	07.10	02.00		Due To 11KV Jumper Cut Near Mamilla (V)	-
2		Makthal	Kahanpur	11KV	Narayanpet	01.20	06.30	05.10		No Visible Fault	-
3		Gundumal	APPAIPALLY (CHALLAPUR)	11KV	Narayanpet	09.50	10.35	00.45		Due to Insulator fail at Appaipally Thanda	-
4		Nancherla	KOMIREDDYPALLY	11KV	Narayanpet	11.10	13.10	02.00		Due to Squarrel fallen on 11KV line at Komireddypally(V)	-
5		Krishna	THANGADI	11KV	Narayanpet	07.30	12.30	05.00		Due to Tree Branch Fallen on 11KV Line and 3 lines cut Near Railway Track	-
6		Krishna	CHEGUNTA	11KV	Narayanpet	11.10	14.00	02.50		Due to Insulator Fail Near Krishna River	-
7		KOTAKONDA	TIRUMALAPUR	11KV	Narayanpet	08.24	09.15	00.51		Due to phase to phase at Tirumalapur(V)	-
8		KOTAKONDA	TIRUMALAPUR	11KV	Narayanpet	09.20	09.54	00.34		Due to phase to phase at Tirumalapur(V)	-
9		KYATHANPALLY	WATTUGUNDLA	11KV	Narayanpet	02.00	08.58	06.58		Due to 11KV line and LT line mixed at Kamsanpally(V)	-
10		KANUKURTHY	KANUKURTHY	11KV	Narayanpet	01.48	07.08	05.20		Due to 11KV line and LT line mixed at Ulligundam(V)	-
11		EKLASPUR	KANMANUR	11KV	Narayanpet	12.10	14.28	02.18		Due 11KV line cut at Kanmanoor(V)	-
12		GOTUR	GOTUR	11KV	Narayanpet	11.40	13.22	01.42		Due to 11KV Line cut at Gotur(V)	-
1	NLG	Annaram	Sangem	11KV	Suryapet	07.30	10.10	02.40	E/L	Tree branch fallen on the line	-
2		Dirsincherla	N S Gudem	11KV	Huzurnagar	07.40	09.00	01.20	EL	11 KV LINE SNAPPED	-
3		Nakrekal	Marrur	11KV	Nalgonda	11.17	15.25	04.08	EL	Tree falen on line at Thatikal road	-
4		Palem	Ogodu	11KV	Nalgonda	12.20	17.00	04.40	EL	Tree branches falen on line at Ogodu village	-
5		Ch.Laxmapur	Malkapur	11KV	Bhongir	08.05	10.00	01.55	EL/OL	11 KV Disc failed near Malkapur village	-
6		Juloor	Kapraipally	11KV	Choutuppal	08.31	11.05	02.34	EL/OL	100kva DTR Failed near Mukthapur Village	-
7		Puligilla	Kanchanapally	11KV	Choutuppal	05.00	08.25	03.25	EL/OL	11 KV Insulator failed near Goligudem village	-
1	MDK	Kistareddypet	Industrial	11KV	Patancheru	13.15	14.15	01.00		BD due to CTPT failed	-
1		DR.Pally SS	DR Pally Feeder	11KV	Gajwel	13:05	15:05	2:00		11Kv line Cut	-
2		DR.Pally SS	Giripally Feeder	11KV	Gajwel	16:25	18:11	2:14		11KV pole damaged	-
3		Gajwel Pregnapur SS	Town-I Feeder	11KV	Gajwel	14:30	15:20	0:50		OL/EL Tripping	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
4	SDPT	Gajwel Pregnapur SS	Town-I Feeder	11KV	Gajwel	15:30	16:15	0:45		Umamaheshavara appartment Cable line Short circuted	-	
5		Gajwel SS	BV Pur	11KV	Gajwel	7:40	11:04	3:24		11KV disk faile	-	
6		Jagdevpur SS	Jagdevpur Indu Feeder	11KV	Gajwel	15.30	18.30	03.00		11KV insulatar faile	-	
7		Pregnapur SS	Pregnapur Town Feeder	11KV	Gajwel	15.40	17.10	01.30		Insulatar fail	-	
8		Gowraram SS	Gowraram Town Feeder	11KV	Gajwel	09.40	11.55	02.15		11Kv line Cut	-	
9		Gowraram SS	Gowraram Town Feeder	11KV	Gajwel	15.30	17.20	02.10		Tree has fallen the line	-	
10		Gowraram SS	Gowraram AGL Feeder	11KV	Gajwel	17.45	18.55	01.10		AB Switch open due to hevay rain	-	
11		Gowraram SS	Mailaram feeder	11KV	Gajwel	17.20	17.50	00.30		AB Switch open due to hevay rain	-	
12		Cheelasagar SS	Annasagar Feeder	11KV	Gajwel	14.40	19.00	04.20		11Kv line Cut	-	
13		Mulugu SS	Nagireddypally Feeder	11KV	Gajwel	09.25	13.06	03.41		11KV insulatar faile	-	
14		Duddeda SS	Selampu AGL Feeder LC.	11KV	Gajwel	21.40	10.00	12.20		11Kv line Cut	-	
15		Dommata SS	Gajulapally Feeder	11KV	Gajwel	7:10	10:34	3:24		DTR core Insulatar faile	-	
1		RR N	Somashila	Ramalayam	11KV	Kukatpally	02.36	03.55	01.19		11kv Breaker Problem In Sub -station	-
2			Aliabad	HBL	11KV	Medchal	03.15	06.15	03.00		Tree Fallen on the 11KV Line at near Sangeeth Function Hall, Main Road Aliabad	-
1		HYD N	Macha Bollarum	Chinthal Bazar	11KV	C-VI	06.53	08.30	01.37	EL,OL	No Visible Fault	Arranged B/F on 1KV Bollarum P.S feeder
2	Raheja		R.M.U - 3	11KV	X	07.25	09.15	01.50	EL	HT Service CT PT nut & bolt fault	-	
3	Zamistanpur		S.P College	11KV	V	10.59	12.08	01.09	EL,OL-Bph	AB Cable fault at Skandagiri Temple	-	