

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		7		7		7			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		5		5		5			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>9</b>	<b>2</b>	<b>9</b>	<b>2</b>	<b>9</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>19</b>	<b>2</b>	<b>19</b>	<b>2</b>	<b>19</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 09.06.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Vepoor	33KV	Narayanpet	03.35	08.15	04.40	EL	Pin Insulator Damaged at Chenna Reddy Pally		NO
1	MDK	Zaheerabad	Mirzapur B	33KV	Zaheerabad	18.30	20.05	01.35		BD due to Insulator failed		-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 09.06.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Salkarpet	Thallapump	11KV	Narayanpet	12.30	17.00	04.30		Squarrel Fallen on the 11KV Line at Thallapump AGL	-
1	NLG	D Nagaram	Vardhamanukota	11KV	Suryapet	09.55	12.20	02.25	E/L	11Kv Conductor snapped	-
2		Penpahad	Dubbathanda	11KV	Suryapet	10.30	12.30	02.00	E/L	11Kv Insulator failed	-
3		Bollepally	Jampally	11KV	Bhongir	02.50	08.05	05.15	E/L	11Kv Line snapped at Sitaram well near jampally (V)	-
4		Alair 2	Alair Agl	11KV	Bhongir	01.00	08.55	09.03	E/L	11kv Insulator failed at SS-13 Near Alair	-
5		Juloor	Peddagudem	11KV	Choutuppal	02.43	09.45	07.02	E/L	11kv Insulator failed near Peddagudem(V)	-
1	MDK	Kistareddypet	Industrial	11KV	Patancheru	05.40	07.27	01.47		BD due to Insulator failed	-
2		Bollaram - II	Kottam	11KV	Patancheru	18.20	19.25	01.05		BD due to Insulator failed	-
3		Sangareddy Town-II	Filterbed	11KV	Sangareddy	19.00	21.15	02.15		BD due to Insulator failed	-
1	RR N	Subhash Nagar	Praghatools	11KV	Medchal	02.35	04.10	01.35	EL	Rope Touched to the Channel at BSNL R & B	-
2		Shameerpet	Leo Meridian	11KV	Medchal	02.45	06.30	03.45	EL/OL	No Fault	-
3		Town Medchal	Balaji Nagar	11KV	Medchal	02.10	03.50	01.40	EL/OL	Cloth fallen on the 11KV Line at Mukunda Theater	-
4		Town Medchal	Country Club	11KV	Medchal	02.50	04.30	01.40	EL	Tree fallen on the 11KV Line at Country Club	-
5		ICICI	Bharath Biotech	11KV	Medchal	02.48	06.18	03.30	EL/OL	No Fault	-
6		Nuthankal	Nuthankal	11KV	Medchal	05.10	07.05	01.55	EL	Bird fallen on the 11KV Line at Nuthankal	-
7		Town Medchal	Housing Board	11KV	Medchal	05.45	07.10	01.25	EL	Tree fallen on the 11KV Line at Anand Hospital	-
1	RR E	Uppal Kalsa	Venkateshwara Temple	11KV	Habsiguda	03.20	04.20	01.00		Tripped on EL due to AB switch blade repiar at venkateshwara temple & feeder	B/F from Chilka nagar feeder due to Breaker mechanical problem in SS
2		Narapally	Narapally Indl	11KV	Keesara	02.15	04.45	02.30		Flexi Fallen on 11KV line at Venkatadri Township	-
1	HYD N	Bhudevi Nagar	Maruthi Nagar	11KV	C-VI	15.00	16.24	01.24	EL,OL	Cable Fault	Arranged B/F on 11KV Nagadevatha Temple fdr