

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 4 | | 4 | | 4 | | | |
| 7 | RR(E) | 168 | 403 | | 3 | | 3 | | 3 | | | |
| 8 | Hyd | 194 | 1044 | | 7 | | 7 | | 7 | | | |
| | Total | 606 | 3055 | 0 | 14 | 0 | 14 | 0 | 14 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 1 | 9 | 1 | 9 | 1 | 9 | | | |
| 2 | NLG | 144 | 988 | | 25 | | 25 | | 25 | | | |
| 3 | MDK | 107 | 933 | | 4 | | 4 | | 4 | | | |
| 4 | SDPT | | | | 24 | | 24 | | 24 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 1 | 62 | 1 | 62 | 1 | 62 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 1 | 76 | 1 | 76 | 1 | 76 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 11.06.2021

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|----------------------------------|-----------------------|---------------------------------------------|
| 1 | MBNR | Marikal | Devarkadra | 33KV | Narayanpet | 07.20 | 08.10 | 00.50 | E/L | Pin binding failed at Devarkadra | Devarkadra | AB Switch Opened at Devarkadra at 08:10Hrs. |

TSSPDCL - LMRC / Corporate office

Date: 11.06.2021

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|-----------------------|------|----------------------|-------|-------|----------|------------------|--------------------------------------------------|---------------------------|
| 1 | MBNR | Kaverammabet | Bandamidipally | 11KV | Jadcherla | 09.50 | 11.45 | 01.55 | | 11KV Jumper cut near Bandamidipally | No |
| 2 | | Mallaboinpally | Bureddypally | 11KV | Jadcherla | 00.00 | 07.20 | 07.20 | | 11KV Insulatoe fail near Bureddypally | No |
| 3 | | Maganoor | WADWAT | 11KV | Narayanpet | 16.10 | 16.36 | 00.26 | | HT/LT at wadwat agl | No |
| 4 | | MADDUR | RERNIVETLA (PADRIPAD) | 11KV | Narayanpet | 9:18 | 10:25 | 1:07 | | Tree branch fallen on 11kv line at pediripad vlg | No |
| 5 | | KOTHAPALLY | LINGALCHEDU | 11KV | Narayanpet | 12:25 | 14:07 | 1:42 | | 11kv lines mixed at komur vlg | No |
| 6 | | KOTHAPALLY | KOTHAPALLY | 11KV | Narayanpet | 14:42 | 16:20 | 1:38 | | Phase to phase at kothapally vlg | No |
| 7 | | SALKARPET | PAGIDIYAL | 11KV | Narayanpet | 2:28 | 8:35 | 6:07 | | 11kv line cut at pagidyal vlg | No |
| 8 | | KYATHANPALLY | WATTUGUNDLA | 11KV | Narayanpet | 9:30 | 11:53 | 2:23 | | LT line cut and fallen on DTR at kamsanpally vlg | No |
| 9 | | KONDAPUR | CHARLAPALLY | 11KV | Narayanpet | 09.00 | 11.00 | 02.00 | | Pin insulator fail at charlapally agl | No |
| 1 | | Narketpally | Mandra | 11KV | Nalgonda | 14:40 | 17:10 | 2:30 | EL | 11KV Jumper cut | No |
| 2 | | Katangur | Dugunelly | 11KV | Nalgonda | 04.00 | 07.00 | 03.00 | EL | 11KV Jumper cut | No |
| 3 | | Katangur | Bollepally | 11KV | Nalgonda | 04.00 | 08.30 | 04.30 | EL | Tree branch fallen on 11KV line | No |
| 4 | | Katangur | Kalimera | 11KV | Nalgonda | 04.00 | 08.30 | 04.30 | EL | 11KV Jumper cut | No |
| 5 | | Thurkapally | Thurkapally | 11KV | Nalgonda | 04.18 | 08.06 | 03.48 | EL | Tree fallen on 11KV line | No |
| 6 | | Eduloor | Parada | 11KV | Nalgonda | 04.15 | 09.20 | 05.05 | EL | Tree branch fallen on 11KV line | No |
| 7 | | Yerraram | Yerraram | 11KV | Devarakonda | 10.40 | 12.21 | 01.41 | EL | 11 Kv Insulator failed | No |
| 8 | | Singarajpally | Veeraboinapally | 11KV | Devarakonda | 11.10 | 12.22 | 01.12 | EL | 11 Kv Conductor Snapped | No |
| 9 | | Singarajpally | Bramanapally | 11KV | Devarakonda | 11.10 | 12.32 | 01.22 | EL | 11 Kv Insulator failed | No |
| 10 | | Kothapally | Kasurajpally | 11KV | Devarakonda | 04.50 | 11.15 | 06.25 | EL | 11 Kv Conductor Snapped | No |
| 11 | | Penpahad | SR Palem | 11KV | Suryapet | 09.15 | 10.30 | 01.15 | E/L | Insulator failed | No |
| 12 | | Reddygudem | Gorentla | 11KV | Suryapet | 05.45 | 09.53 | 04.08 | E/L | Disc failed | No |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged | |
|------|----------|--------------------|----------------------|------------|----------------------|------------|-------|----------|------------------|--------------------------------------------------------------------|---------------------------|----|
| 13 | NLG | T Giri | Thonda | 11KV | Suryapet | 06.00 | 09.30 | 03.30 | E/L | Conductor snapped | No | |
| 14 | | Gundepuri | Pasthala | 11KV | Suryapet | 06.00 | 11.50 | 05.50 | E/L | Pole damaged and Insulator failed | No | |
| 15 | | Dirsincherla | Yallapuram | 11KV | Huzurnagar | 06.10 | 08.00 | 01.50 | EL | 11 KV LINE SNAPPED | No | |
| 16 | | Anathagiri | Mogalaikota | 11KV | Huzurnagar | 22.50 | 01.05 | 02.15 | EL | 11 KV LINE SNAPPED | No | |
| 17 | | Solipet | Peraram | 11KV | Bhongir | 03.15 | 09.40 | 06.25 | EL/OL | 11 kv Line snapped near Peraram village | No | |
| 18 | | Sharajipet | Sharajipet | 11KV | Bhongir | 04.05 | 06.05 | 02.00 | EL/OL | 11 kv Disc failed near Sharajipet village | No | |
| 19 | | Golankonda | Vanchyagudem | 11KV | Bhongir | 05.00 | 08.05 | 03.05 | EL/OL | 11 kv Insulator failed near Vanchyagudem village. | No | |
| 20 | | Datherpally | Jangampally | 11KV | Bhongir | 04.20 | 09.30 | 05.10 | EL/OL | 11 kv Insulator failed near Jangampally village | No | |
| 21 | | Datherpally | Datherpally | 11KV | Bhongir | 05.30 | 10.23 | 04.53 | EL/OL | 11 kv Line snapped at Jambavi near datherpally village. | No | |
| 22 | | Addagudur | Addagudur | 11KV | Bhongir | 02.00 | 09.00 | 07.00 | EL/OL | 11 KV Insulator failed near Sub station 10 th pole | No | |
| 23 | | S.Lingotam | S.Lingotam Agl | 11KV | Choutuppal | 02.00 | 10.08 | 08.08 | EL/OL | 11 kv line snapped near Lingotam village. | No | |
| 24 | | Choutuppal | Jublakaply | 11KV | Choutuppal | 05.45 | 10.45 | 05.00 | EL/OL | 11 kbv Disc failed at KCR Colany near Jublakaply village | No | |
| 25 | | Puligilla | Puligilla | 11KV | Choutuppal | 5:45 | 8:10 | 2:25 | EL/OL | 11 kv Disc failed at J.Chandra reddy well. Near Puligilla village. | No | |
| 1 | | MDK | Bonthapally | Newland | 11KV | Patancheru | 15:45 | 17:45 | 2:00 | | Jumper Cut | No |
| 2 | | | Hathnoora | Town Indl. | 11KV | Jogipet | 08.50 | 10.50 | 02.00 | | Conductor Snapped | No |
| 3 | Dundigal | | AFA | 11KV | Patancheru | 08.40 | 09.50 | 01.10 | | Tree branch fallen on the line | No | |
| 4 | Bollaram | | Town -I | 11KV | Patancheru | 12.00 | 14.00 | 02.00 | | Conductor Snapped | No | |
| 1 | SDPT | Rampur | JP Thanda | 11KV | Siddipet | 9:00 | 11:10 | 2:10 | | Insualtor failed | No | |
| 2 | | Rampur | Palamakula | 11KV | Siddipet | 10.00 | 12.20 | 02.20 | | Disc failed | No | |
| 3 | | Thornala | Thornala | 11KV | Siddipet | 14.50 | 18.20 | 03.30 | | Jumper cut | No | |
| 4 | | Irkode | Irkode | 11KV | Siddipet | 05.30 | 07.30 | 02.00 | | Jumper cut | No | |
| 5 | | THIGUL SS | THIGU AGL | 11KV | Gajwel | 13.44 | 15.57 | 02.13 | | 11KV LINE CUT | No | |
| 6 | | CHATLAPALLY SS | ANTHAIGUDA | 11KV | Gajwel | 11.10 | 13.20 | 02.10 | | Disc failed | No | |
| 7 | | CHATLAPALLY SS | AGL FEEDER | 11KV | Gajwel | 12.05 | 12.25 | 00.20 | | Copper Patti cut | No | |
| 8 | | PREGNAPUR | GUNDANNAPALLY AGL | 11KV | Gajwel | 10.35 | 11.36 | 01.01 | | Insualtor failed | No | |
| 9 | | ERRAVALLY | PS FEEDER | 11KV | Gajwel | 09.29 | 09.45 | 00.16 | | Disc failed | No | |
| 10 | | ERRAVALLY | NARSANNAPETA | 11KV | Gajwel | 08.10 | 09.02 | 00.58 | | Disc failed | No | |
| 11 | | ERRAVALLY | AGL FEEDER | 11KV | Gajwel | 11.20 | 12.37 | 01.17 | | 100KV DTR Copper Patti cut | No | |
| 12 | | DAMARAKUTA SS | DAMARAKUTA | 11KV | Gajwel | 15.30 | 19.40 | 04.10 | | Disc failed and Insualtor failed | No | |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|------------------------------------------------|------|----------------------|-------|-------|----------|------------------|-------------------------------------------------------------------|-----------------------------------------|
| 13 | | WARDARAJPUR SS | SHIVARVENKATAPUR | 11KV | Gajwel | 23.20 | 08.20 | 09.00 | | Disc failed | No |
| 14 | | SEETHARAMPALLY SS | SEETHARAMPALLY | 11KV | Gajwel | 06.20 | 11.00 | 06.40 | | Tree branch fallen on the line | No |
| 15 | | MULUGU SS | MULUGU TOWN | 11KV | Gajwel | 06.24 | 07.44 | 01.20 | | Jumper cut | No |
| 16 | | MULUGU SS | NARSAMPALLY | 11KV | Gajwel | 21.06 | 06.06 | 09.00 | | Jumper cut | No |
| 17 | | MULUGU SS | MULUGU AGL | 11KV | Gajwel | 21.20 | 06.04 | 08.44 | | Jumper cut | No |
| 18 | | MULUGU SS | MULUGU TOWN | 11KV | Gajwel | 12.35 | 13.15 | 00.40 | | Jumper cut | No |
| 19 | | THUNKIBOLARAM SS | DASARLAPALLY INDUSTRIAL | 11KV | Gajwel | 14.30 | 15.30 | 01.00 | | AB Switch open | No |
| 20 | | DUDEEDA | INDUSTRIAL | 11KV | Gajwel | 16.16 | 17.20 | 01.04 | | Due to Rain | No |
| 21 | | Potharam | Vangaramaipally | 11KV | Husnabad | 02.45 | 07.05 | 04.20 | | Tree fallen on the line | No |
| 22 | | Gandipally | Ramavaram | 11KV | Husnabad | 00.00 | 07.00 | 07.00 | | Tree fallen on the line | No |
| 23 | | Dharmaram | Dharmaram (R.) | 11KV | Husnabad | 09.00 | 09.40 | 00.40 | | Tree fallen on the line | No |
| 24 | | Komuravelly | Komuravell 24 Hrs | 11KV | Husnabad | 0:00 | 5:45 | 5:45 | | CTPT Failed | No |
| 1 | RR N | Devarayamjal | Kottapet | 11KV | Medchal | 5:40 | 10:30 | 4:50 | | 2 Nos. Jumper cut & replaced at Air Force Wall & near SS Opposite | No |
| 2 | | Thurkapally | Thurkapally | 11KV | Medchal | 14.20 | 15.15 | 00.55 | | 11KV Line AB Switch Opened at Damodhar Reddy Thota | No |
| 3 | | Gowdavelly | Ayodhya | 11KV | Medchal | 15.20 | 16.18 | 00.58 | | 11KV Disc failed at Gowdavelly Village | No |
| 4 | | Gowdavelly | Ayodhya | 11KV | Jeedimetla | 03.45 | 07.45 | 04.00 | | 11kv Pin Insultor Failure At Nagaloor | No |
| 1 | RR E | Nacharam Indore | Vyjayanthi | 11KV | Habsiguda | 3:21 | 4:20 | 0:59 | | Line patrolling done but no visible fault found | No |
| 2 | | IDA Uppal | Jersey | 11KV | Habsiguda | 04.20 | 05.10 | 00.50 | | 11KV Jumper cut at Ashu Package company | No |
| 3 | | Narapally | Narapally Indl | 11KV | Keesara | 14.35 | 15.55 | 01.20 | | Tree branches fallen on 11KV line at Venkatadri Township | No |
| 1 | HYD N | Pragatools | R.R.Nagar | 11KV | VI | 12.28 | 13.50 | 01.22 | OL-Bph | Tree branches fallen on line at Jangal Bit | No |
| 1 | HYD C | Fever Hospital | Fever Hospital | 11KV | II | 00.05 | 02.05 | 02.00 | EL | Disc Insulator flash over at Bank of Baroda | No |
| 2 | | Z.P.Office | Ramleela Maidan | 11KV | I | 08.09 | 09.45 | 01.36 | EL | Disc Insulator flash over at Khairathabad | No |
| 3 | | Public Garden | Tata Tele Service (HT Service - Dedicated fdr) | 11KV | I | 07.11 | 09.30 | 02.19 | EL,OL-Yph | I/C Cable fault due to Consumer side load problem | Arranged B/F on 11KV Gunfoundary feeder |
| 4 | | Asif Nagar | Mehdipatnam Cable | 11KV | VII | 18.40 | 22.30 | 03.50 | EL | Pin Insulator flash over at Molbery Store DTR | No |
| 5 | | Gudimalkapur | Murad Nagar | 11KV | VII | 20:09 | 21:16 | 1:07 | EL | I/C AB Cable fault | Arranged B/F on 11KV Anjuman fdr |
| 6 | | S.D.Hospital | Ahmed Nagar Cable | 11KV | VII | 20.09 | 21.59 | 01.50 | EL,OL-Yph | Cable fault at Opp. Saibaba Temple | Arranged B/F on 11KV Military fdr |