

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	10	0	10	0	10	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT			1	3	1	3	1	3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	6	1	6	1	6	0	0	
	Grand Total	1082	6468	1	16	1	16	1	16	0	0	

TSSPDCL - LMRC / Corporate office

Date: 20.06.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Chandlapur	Jakkapur	33KV	Siddipet	13:30	17:12	3:42		B/D Pole damage	Jakkapur	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Badepally	Signalgadda	11KV	Jadcherla	11.40	12.33	00.53		HT/LT Pole Damaged near Boyalakunta Road	No
1	NLG	Nakrekal	Nomula	11KV	Nalgonda	7:40	8:40	1:00	EL	Insuletor Failed	No
2		Repala	Kalakova	11KV	Huzurnagar	12.50	14.30	01.40	EL	11 KV Line snapped	No
1	SDPT	Erravelly SS	Erravelly AGL	11KV	Gajwel	16:05	16:27	0:22		Disc failed	No
2		Doulthabad SS	Lingarajpally	11KV	Gajwel	14:47	15:12	0:26		11KV Insulatar failed	No
3		Akkannapet	Pakilnaik Thanda	11KV	Husnabad	00.00	06.00	06.00		Jumper cut	No
1	RR N	UMCC	Gajularamaram	11KV	Medchal	18:00	19:05	1:05		11KV Line cut	No
2		Town Medchal	Jyothi Nagar	11KV	Medchal	13.00	13.40	00.40		Tree Branch fallen on the 11KV line at Jyothi Nagar	No
1	RR E	Mallapur 2	Narsimha nagar	11KV	Habsiguda	11:25	12:45	1:20		Insulator failed at 160KVA T/F at MS point	No
2		Uppal	Navbharath	11KV	Habsiguda	08.20	09.20	01.00		11KV Brass patti cut at DSL Mall	No
3		Sainikpuri	Vijayapuri	11KV	Sainikpuri	09.40	11.05	01.25		UG Cable failed on Vijayapuri	Load Add on Sainikpuri feeder
4		Moula-Ali	HCL	11KV	Sainikpuri	16.43	18.03	01.20		UG Cable fail at SS Main Gate on HCL	Load Add on Meerpet Feeder
5		Aushapur	Madharam	11KV	Keesara	16:00	16:40	0:40		11KV Jumper cut at Madharam village	No
1	HYD N	Bowenpally	I.A.F.	11KV	VI	15.36	16.46	01.10	OL-R&Bph	Tree branches fallen on lines at I.A.F.Quarters	No
1	HYD S	Arundathi Colony	Neelam Center	11KV	III	23.10	00.15	01.05	EL,OL	I/C Cable fault	Arranged B/F on 11KV Saibaba Nagar fdr
1	HYD C	Zamistanpur	Shastry Nagar	11KV	II	14.25	17.58	03.33	EL	UG Cable fault at Rama Lahari Apts	At 17:44Hrs Partial loads added on 11KV Parsigutta fdr & remaining loads charged from SS