

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		2		2		2			
3	MDK	107	933		1		1		1			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	0	9	0	9	0	9	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 22.06.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Manthangoud	Manthangode Biogas	11KV	Narayanpet	07.00	09.00	02.00		Tree branch fallen on 11kv line at manthangode vlg	-
1	NLG	Timmareddy gudem	Ganapavaram	11KV	Huzurnagar	06.30	07.45	01.15	EL	11 KV LINE SNAPPED	-
2		Alingapuram	Gundlapahad	11KV	Huzurnagar	07.30	09.00	01.30	EL	11 KV LINE SNAPPED	-
1	MDK	EPIP-II	Ufoam	11KV	Sangareddy	11.05	11.50	00.45		BD Due to Jumper Cut	-
1	SDP	Mustabad X-Road	Gadichaerlapally	11KV	Siddipet	07.30	08.00	00.30		B/D due to insulator failed	-
2		Gurrallagondi	Malyala	11KV	Siddipet	13.03	14.25	01.22		B/D due to insulator failed	-
1	RR N	Devarayamjal	Kottapet	11KV	Medchal	10.00	12.25	02.25	BD	No Fault	-
2		Devarayamjal	Kottapet	11KV	Medchal	13.05	14.05	01.00	BD	No Fault	-
3		Thumkunta	Thumkunta	11KV	Medchal	19.40	21.15	01.35	BD	Line AB Switch opened at Sprots School	-