

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4	3	4	3	4	3			
2	NLG	144	988		10		10		10			
3	MDK	107	933		1		1		1			
4	SDPT			2	11	2	11	2	11			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	25	6	25	6	25	0	0	
	Grand Total	1082	6468	6	27	6	27	6	27	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	G.R Cable	33KV	Jadcherla	00.21	00.41	00.20	E/LO/L	B Phase Jumper Cut	G.R Cable	AB Switch Opened at Kethireddypally
2		Maddur	Kankuthy	33KV	Narayanpet	18.25	19.00	00.35	EL	No Visible Fault Due to Rain	Kankuthy	Alternate Supply Arranged from 33KV Dhanwada 33/11KV Appampally
3		Maddur	Vepoor	33KV	Narayanpet	19.15	20.55	01.40	EL	No Visible Fault Due to Rain	Vepoor	No
4		Marikal	Koilkonda Water Grid	33KV	Narayanpet	21:50	22:20	0:30	EL	Due to Line Fault & Light Rain	Koilkonda Water Grid	Due to Loads Devertion to Kondapur Feeder at 22:20Hrs
1	SDPT	Mustyala	Komuravelly	33KV	Husnabad	4:30	6:40	2:10		Tree branch fallen on the line, same rectified		No
2		Thukkapur	Mirdoddy	33KV	Gajwel	07.10	08.20	01.10		Disc failure		No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	SALKARPET	THALLAPUMP	11KV	Narayanpet	12.10	14.15	02.05		Due to 11kv pin insulator fail and line cut at chintagutta	No
2		Paspula	PASUPULA BHEEMA LIFT	11KV	Narayanpet	14.34	16.50	02.16		Due to DTR repair at paspula vlg	No
3		Mustipally	ANUGONDA	11KV	Narayanpet	13.20	14.50	01.30		Due to 11kv line touched to channel at DTR at anugonda vlg	No
1	NLG	Garidepally	Appanapet	11KV	Huzurnagar	5:30	7:30	2:00	EL	11 KV LINE SNAPPED	No
2		Palakeedu	Palakeedu	11KV	Huzurnagar	05.50	08.00	01.50	EL	11 KV LINE SNAPPED	No
3		Repala	N S Gudem	11KV	Huzurnagar	10.15	11.30	01.15	EL	11 KV JUMPER CUT	No
4		Penpahad	Anajipuram	11KV	Suryapet	08.30	11.05	02.35	E/L	Conductor snapped	No
5		Katangur	Mallaram	11KV	Nalgonda	03.30	10.00	06.30	E/L	Thatikomma fallen on 11KV line	No
6		Palem	Ogodu	11KV	Nalgonda	06.10	09.30	03.20	E/L	11KV jumper cut	No
7		Pamanagundla	Erasanigudem	11KV	Nalgonda	12.45	15.56	03.11	E/L	11KV AB switch open	No
8		Thurkapally	Hydelapoor	11KV	Nalgonda	14.43	16.08	01.25	E/L	11KV Jumper cut	No
9		Mushampally	Mushampally AGL	11KV	Nalgonda	10.20	12.10	01.50	E/L	11KV Jumper cut	No
10		Mushampally	Muthyalamma	11KV	Nalgonda	4:00	10:00	6:00	E/L	11KV Jumper cut	No
1	MDK	Inole	Peddakanjarla	11KV	Sangareddy	11:24	13:15	1:51		Tree branch fallen on the line	No
1	SDPT	Thotapally	Mallampally	11KV	Husnabad	19:25	20:25	1:00		Tree branch fallen on line, same rectified	No
2		Dhoolimitta	Dhoolimitta Agl	11KV	Husnabad	04.00	11.30	07.30		Insulator failure, same rectified	No
3		Narsapur	Karimnagar Indl	11KV	Siddipet	04.03	09.50	05.47		B/D Tree branch fall on the line	No
4		Mustabad X road	DE Office	11KV	Siddipet	04.10	07.00	02.50		B/D Tree branch fall on the line	No
5		Narmetta	Thimmaipally	11KV	Siddipet	10.50	12.55	02.05		B/D Disc fail & LC.No.17654	No
6		Laxmidivipally	Ibrahimpur	11KV	Siddipet	07.20	08.50	01.30		B/D Tree brach failed on the line	No
7		Raghothampally	Raghothampally	11KV	Siddipet	02.35	06.20	03.45		B/D Insulater fail	No
8		Raghothampally	Akaram	11KV	Siddipet	02.40	08.00	05.20		B/D Tree brach fall on the line	No
9		Peddagundavelly	Balwanthapur	11KV	Siddipet	03.30	09.30	06.00		B/D Insulater fail & LC.No.0235	No
10		Kodakandla SS	KODAKANDLA	11KV	Gajwel	01.55	03.54	01.59		POLE BROKEN	No
11		Markook SS	MARKOOK AGL	11KV	Gajwel	10:20	14:00	3:40		JUMPER CUT	No
1	RR N	Devarayamjal	Kottapet	11KV	Medchal	13:00	14:15	1:15		11KV Brass Patti cut & Replaced at DMC	No
1	HYD S	Falaknuma	Aliyabad	11KV	III	02.30	04.03	01.33	EL	RMU Cable fault at Sha Ghouse	No