

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	0	9	0	9	0	9	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	11	0	11	0	11	0	0	
	Grand Total	1082	6468	0	20	0	20	0	20	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 30.06.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Indugula	Malparajugudem	11KV	Nalgonda	01.28	06.45	05.17	EL	11 KV Jumper Cut	-
2		Kethepally	Chikatigudem	11KV	Nalgonda	01.40	07.20	05.40	EL	11 KV Jumper Cut	-
3		Palem	Ogodu	11KV	Nalgonda	14.50	16.05	01.15	EL	11 KV Jumper Cut	-
4		Gaddipally	Medaram	11KV	Huzurnagar	03.45	07.30	03.45	EL	11 KV LINE SNAPPED	-
5		Munagala	Barakathgudem	11KV	Huzurnagar	08.40	10.00	01.20	EL	11 kv jumper cut	-
6		Gurraladandi	Jampally	11KV	Bhongiri	06.00	08.33	02.33	EL/OL	11 kv line snapped near Jampally village	-
7		Veluvorthy	Sunkishala	11KV	Choutuppal	06.00	08.30	02.30	EL/OL	11 kv Line snapped at Batthepeu. Bixapathy well near Sunkishala village	-
1	SDP	Markook	Sneha Industrial	11KV	Gajwel	15.35	17.25	01.50		Disc Failed	-
2		Karkapatla	Karkapatla	11KV	Gajwel	15.30	17.30	02.00		Fuse of Call & DTR Repair	-
3		Pamulaparthi	Express Feeder	11KV	Gajwel	18.30	19.10	00.40		Insulator Failed	-
4		Kammarlapally	kothapally	11KV	Siddipet	01.42	08.15	06.33		B/D tree fall down Lc no 8417	-
1	RR N	Laxmapur	IDA Laxmapur	11KV	Medchal	08.20	09.45	01.25	BD	11KV Jumper Cut & Replaced at Government Hospital, MC Pally	-
2		Laxmapur	IDA Laxmapur	11KV	Medchal	19.00	20.10	01.10	BD	No Fault	-
1	RR E	Moula ali	Jawahar Nagar	11KV	Sainikpuri	03.30	04.45	01.15		Tree branches fallen on 11KV line near Unani Hospital (Artisian Raju)	-
2		Moula ali	Kailasagiri	11KV	Sainikpuri	14.50	16.20	01.30		Tree branches fallen on 11Kv line at beside Word Office & 11Kv jumper cut at Sagar Appartment (L.Insp Srikanth)	-
1	HYD N	Chilkaiguda	Dandu Pentaiah	11KV	V	00.50	02.58	02.08	EL,OL-R&Bph	RMU End Kit failed	Arranged B/F on 11KV MCH Park feeder
2		Nehru Nagar	Teachers Colony	11KV	C-VI	14.28	16.40	02.12	EL	Road crossing UG Cable fault at Teachers Colony	Arranged B/F on 11KV Ramser Cafe fdr
3		Marredpally	Jyothi Colony	11KV	C-VI	16.00	17.25	01.25	EL,OL-Yph	Cable Fault	Arranged B/F on 11KV Vasavi Nagar fdr
4		R.P.Nilayam	Nagadevatha Temple	11KV	C-VI	17.17	18.29	01.12	EL	AB Switch fault at Lothukunta Rly.Track	-----
1	HYD S	C.R.P.F.	Baba Nagar	11KV	III	09.35	11.30	01.55	EL,OL-Bph	AB Cable fault	Arranged B/F on 11KV C-Block fdr