

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		5		5		5			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	11	0	11	0	11	0	0	
	Grand Total	1082	6468	0	14	0	14	0	14	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.03.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
										Nil		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 01.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothapally	Nidjinta Rural	11KV	Narayanpet	12.03	12.50	00.47		Tree Branch Fallen on 11KV line	-
2		Nancherla	Juvulapally	11KV	Narayanpet	10.45	13.25	02.40		LT/HT at Near Industrial park Near Desaipally(V)	-
3		Paspula	Satyaram	11KV	Narayanpet	10.10	11.00	00.50		Tree Branch Fallen on 11KV line Near Gopulapur(V)	-
4		Perapalla	Shashanpally	11KV	Narayanpet	09.32	11.15	01.43		11KV Line Cut	-
5		Mogal Madka	Mogal Madka®	11KV	Narayanpet	09.12	10.45	01.33		11KV Line Cut	-
1	NLG	Munagala	Thadvai	11KV	Huzurnagar	05.30	07.42	02.15	E/L	11Kv Line Snapped	-
2		Thungathurthy	Ganugubanda	11KV	Suryapet	09.20	12.45	03.25	E/L	11Kv Insulator failed	-
3		B.Ramaram	Jalalpur	11KV	Bhongir	08.55	09.15	00.20	E/L	11kv Disc Failed near Jalalpur (V)	-
4		Mandollagudem	Peddakondur	11KV	Choutuppal	02.00	06.41	04.41	E/L	100 kva DTR failed near Cherilla (V)	-
1	SDPT	MARKOOK	MARKOOK TOWN	11KV	Gajwel	16.10	17.10	01.00		JUMPER CUT	-
2		Akunoor	Akunoor 24 hrs	11KV	Husnabad	17.50	19.45	01.55		25KVA DTR FAILURE	-
1	RR N	Jagathirigutta	Maqdoom Nagar	11KV	Medchal	11.05	11.50	00.45	BD	11KV Line AB Switch Opened at Lenin Nagar Venture(Tree fault)	-
2		Kandlakoya	Kandlakoya	11KV	Medchal	04.30	05.05	00.35	BD	11KV Line Phase to Phase at Pochamma Temple	-
3		Aliabad	LGM Pet	11KV	Medchal	16.32	17.15	00.43	BD	11KV Pole fallen at Kashawada	-