

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	2	1	2	1	2	1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT				3		3		2		1	1 No. 11KV still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>1</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>6</b>	<b>2</b>	<b>5</b>	<b>0</b>	<b>1</b>	

TSSPDCL - LMRC / Corporate office

Date: 04.03.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	33KV Aliabad	33KV	Medchal	12.30	13.40	01.10		33KV Jumper Cut & Replaced at LGM Pet	33KV Aliabad	-
2		132KV Malkaram	33KV Ratnalayam	33KV	Medchal	12.10	13.40	01.30		No Fault	33KV Ratnalayam	-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 04.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Malkapur	Malkapur Agl	11KV	Choutuppal	12.05	14.10	02.05	EL/OL	11KV Line snapped near Malkapur Village	-
1	SDPT	Thadkapally	Thadkapally	11KV	Siddipet	19.35	00.00	04.25		Tripped on Ol& EL, Still under breakdown	-
2		Mulugu	Bailampur	11KV	Gajwel	15.30	10.50	17.20		Conductor snapped	-
3		Mobharasapur	Mobharasapur	11KV	Gajwel	12:12	13:20	01:08		Conductor snapped	-
1	RR N	PrashanthiHills	Mithula Nagar	11KV	Jeedimetla	14.20	17.15	02.55		11kv Disk failure At Pt No- 1173 At MithulaNagar	-
1	HYD S	Moosarambagh	Shalivahana Nagar	11KV	VIII	00.39	03.25	02.46	EL,OL-Yph	Cable fault at Maruthi Classic Apts	Arranged partial loads B/F on 11KV Dilsukh Nagar feeder