

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044									
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3		3		3			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	9	0	9	0	9	0	0	
	Grand Total	1082	6468	0	16	0	16	0	16	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 06.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Makthal	KAHANPUR	11KV	Narayanapet	08.15	12.40	04.25		11KV conductor cut at makthal town	-
2		KANKURTHY	DAMARGIDDA	11KV	Narayanapet	11.53	13.16	01.23		11KV DISC FAILURE, UDMALGIDDA VG	-
3		MARIKAL	TILERU	11KV	Narayanapet	08.05	09.30	01.25		SQUIRREL FALLEN ON THE LINE	-
1	NLG	Gundepuri	Pasthala	11KV	Suryapet	02.40	07.05	04.25	E/L	Conductor snapped	-
2		Yannaram	Kunkuduamula	11KV	Choutuppal	08.50	10.02	01.12	EL/OL	100kva DTR Failed SS-20 Kunkudupamula Village	-
1	SDP	Peddachepyal	Peddachepyal	11KV	Siddipet	07.30	08.50	01.20		B/D Conductor cit	-
2		Peddachepyal	Alwal	11KV	Siddipet	08.00	09.15	01.15		B/D jumper cut	-
3		Maddur	Maddur AGL	11KV	Husnabad	06.55	08.30	01.35		Conductor wire Cut	-
4		Bekkal	Kondapoor	11KV	Husnabad	07.00	11.00	04.00		Tree branch fallen on the Line	-
1	RR N	Jeedimetla-I	HMT Society	11KV	Jeedimetla	01.00	03.45	02.45	EL/OL	AB Cable Failed opp Sagar Hotel	-
2		Kandlakoya	Saigeetha Ashramam	11KV	Medchal	19.08	19.46	00.38	BD	11KV Line cut and replaced at Tata Company	-
1	RR E	Cherlapally-IV	BN Reddy Nagar	11KV	Sainikpuri	08.00	10.30	02.30		11kv Insulator failed and Bird fallen on 11KV line at JayaShankar Statue (AE)	-
2		Cherlapally-III	IOC	11KV	Sainikpuri	22.04	23.44	01.40		Lorry Dash to 11KV Line and Middle Jumper Phase ring cut at IOC Company	-
3		Uppal Kalsa	Veg Market	11KV	Habsiguda	10.10	11.10	01.00		Bird fallen on 11KV line at Post Office Building	-
4		NGRI	HMT Nagar	11KV	Habsiguda	16.45	18.00	01.15		11KV Incoming AB Switch Tale clamp burnt at SS Yard	-
5		Nacharam	Chandamana	11KV	Habsiguda	21.41	22.34	00.53		11KV Line at Agarwal Company & 11KV Jumper cut at Deepak Company Road No.9 IDA Nacharam	-