

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				7		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	12	0	12	0	12	0	0	
	Grand Total	1082	6468	0	17	0	17	0	17	0	0	

TSSPDCL - LMRC / Corporate office

Date: 07.03.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
NIL												

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nancherla	Nancherla	11KV	Narayanapet	07.00	08.00	01.00		Squirrel fallen on the line at Mangampet Tanda	No
2		Midjil	Veljal	11KV	Jadcherla	04.30	08.00	03.30		11Kv Jumper Cut Near Marlabavi Tanda Side	No
1	NLG	Eduloor	Parada	11KV	Nalgonda	10:10	11:20	1:10	EL	11KV Jumpr cut	No
2		Akaram	Vaddipamula	11KV	Nalgonda	15.00	16.40	01.40	EL	11KV Jumpr cut	No
3		Durajpally	Vallabhapuram	11KV	Suryapet	05.30	08.40	03.10	E/L	Conductor snapped	No
1	SDPT	Thigul	Thigul AGL	11KV	Gajwel	11:52	12:35	0:43		11 KV line Cut	No
2		Gowraram SS	Pamulaparthi	11KV	Gajwel	09.10	11.18	02.08		11 KV line Cut	No
3		Gowraram SS	Gowraram town II	11KV	Gajwel	13.35	14.20	00.45		Tree branch fallen on the line	No
4		Mubaraspur Ss	Thirmalapur	11KV	Gajwel	19.34	19.38	00.04		11 KV line cut	No
5		Thadkapally	Thadkapally	11KV	Siddipet	19.35	08.35	13.00		11KV Wire cut	No
6		Gagillapur	Vallampatla	11KV	Husnabad	07.26	08.45	01.19		DTR fault	No
7		Bekkal	Kondapur	11KV	Husnabad	10:00	10:30	0:30		Tree branch fallen on the line	No
1	RR N	UMCC	Sreeram Nagar	11KV	Medchal	10:00	10:55	0:55		11KV AB Cable failed at SCB Nagar	No
2		Subhash Nagar	Padma Nagar	11KV	Medchal	08.48	09.21	00.33		Bird fallen on the 11KV Line at Srilakshmi Apartment	No
3		Devarayamjal	Kottapet	11KV	Medchal	07.45	08.25	00.40		11KV Line cut and replaced at Devarayamjal	No
1	RR E	Mallapur	Sai Nagar	11KV	Habsiguda	6:05	7:50	1:45		11KV End Kit cable failed at SS Yard outside & B/F from 11KV IDA feeder	No
1	HYD N	Bhudevi Nagar	Yadamma Nagar	11KV	C-VI	23.22	00.40	01.18	EL,OL	Vehicle dash to Pole at Telecom Colony	Arranged B/F on 11KV Venugopal Rao Nagar fdr