

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		4		4		4			
2	NLG	144	988		2		2		2			
3	MDK	107	933		2		2		2			
4	SDPT			1	4	1	4	1	4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>12</b>	<b>1</b>	<b>12</b>	<b>1</b>	<b>12</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>18</b>	<b>1</b>	<b>18</b>	<b>1</b>	<b>18</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 09.03.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Mustyala	Cherial	33KV	Husnabad	07.10	07.35	00.25		Kite on lines		-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 09.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Maddur	Chinthaldinne	11KV	Narayanpet	06.30	07.00	00.30		11KV Disc Failed & Jumper cut	-
2		Gudeballeore	Check Post	11KV	Narayanpet	04.50	07.00	02.10		Tree Branches Fallen on the Line Near checkpost	-
3		Kanukurthy	Damargidda	11KV	Narayanpet	11.36	12.01	00.25		11KV Line cut at Gadimunkanpally(V)	-
4		Jaklair	Jaklair	11KV	Narayanpet	07.16	07.40	00.24		Tree Branches Fallen on 11KV Line at Gudigandla(V)	-
1	NLG	Pedaveedu	Krishnathanda	11KV	Huzurnagar	05.00	07.30	02.30	E/L	11Kv Line Snapped	-
2		Paladugu	Paladugu	11KV	Bhongir	06.25	08.20	01.55	E/L	11kv Insulator failed near Raghavapuram (V)	-
1	MDK	Cheryal	Julkal	11KV	Sangareddy	18.00	19.30	01.30		B/D due to Jumper cut	-
2		EPIP-I	Tulasi	11KV	Sangareddy	11.03	13.38	02.35		B/D due to Conductor snapped	-
1	SDPT	Gajwel	Town-2	11KV	Gajwel	07.30	10.30	03.00		Pole damage	-
2		Gurralsafa	Vaddepally	11KV	Gajwel	4:24	9:23	02.59		11KV Line cut	-
3		BASWAPUR	Muthannapet	11KV	Husnabad	07.35	08.40	01.05		LC (jumper cut in yard)	-
4		Guruvannapet	Tapaspally	11KV	Husnabad	17.55	20.30	02.35		3-ph bd 1-ph ok(o/l)	-
1	RR N	Shameerpet	Devarayamjal	11KV	Medchal	00.00	06.40	06.40	BD	11KV Line Cut at Thota Gopal Reddy T/F, Gayatri Temple	-
2		Thumkunta	Thumkunta	11KV	Medchal	06.12	07.10	00.58	BD	Tree Branches fallen on 11KV Line at Mandaipally	-
3		Nuthankal	Nuthankal	11KV	Medchal	09.40	10.15	00.35	BD	Squirrel fallen on the 11KV Line at SS Backside	-
1	HYD N	Chilkaiguda	Gandhi Hospital	NT	Sec-bad	05.50	09.35	03.45	EL,OL-Bph	Cable End Kit failed at Gandhi Hospital Premises	06:20Hrs Idle breaker charged, kept off RMU at Gandhi Hospital (Gandhi Hospital alternate supply taken on Generator )
2		Zamistanpur	Sanjeevapuram	NT	Sec-bad	19.14	20.25	01.11	EL,OL-Rph	Pin Insulator flash over at Moon Rock Bar	-
3	HYD C	Toli Chowki	Paramount Colony	CEN	VII	14.20	15.40	01.20	EL,OL-Yph	HT Jumper cut at Gate No.2, Paramount Colony (At 15:10 partial fdr charged)	-